Mathematical modeling of unsteady response of plate and fin heat exchanger to sudden change in liquid flow rate

Anna Korzeń^{1,*}, and Dawid Taler²

¹Cracow University of Technology, Faculty of Mechanical Engineering, Institute of Thermal Power Engineering, Al. Jana Pawła II 37, 31-864 Cracow, Poland

²Cracow University of Technology, Faculty of Environmental Engineering, Institute of Thermal Engineering and Air Protection, Ul. Warszawska 24, 31-155 Cracow, Poland

Abstract. A mathematical simulation of plate fin and tube heat exchanger will be presented. The transient operation of the heat exchanger was carried out using general numerical model developed in [1]. Reynolds number of the water flowing inside the tubes varied in the range from 4000 to 12000. A detailed analysis of transient response was modeled for growth in the water volume flow in time.

At first, heat transfer correlations for air and water were determined based on the experimental data. Unknown parameters appearing in the relationships for the Nusselt numbers on the air and water-sides were estimated using the least squares method. The power-type form of the relationship for the air-side Nusselt number was used while two correlations of different form were chosen for the water-side Nusselt number. The first is the exponential correlation, and the second form is similar to the relationships of Petukhov-Kirillov and Gnielinski. These correlations were used in the mathematical model of the heat exchanger for the simulation of its transient operation.

The results of the numerical simulations of a heat exchanger using experimentally determined air and water-side heat transfer formulas for calculation of heat transfer coefficient were compared with the experimental data. Very good agreement of computation results (i.e. air and water temperature at the outlet of the heat exchanger) with the experimental data was obtained.

1 Introduction

Publications on the dynamics on the plate fin and tube heat exchangers (PFTHE) are not numerous. Mathematical models of heat exchangers to simulate the non-steady state operation are needed to analyze heat exchangers startup and shutdown, and in PID control systems as well as in control systems using mathematical models of the controlled heat exchanger.

However, most of the works refers to a steady state of these exchangers [2].

* Corresponding author: korzen@mech.pk.edu.pl

The transient response of PFTHE was modeled in [1,3-6]. Usually, fins are modeled as elements with lumped thermal capacity while the equivalent heat transfer coefficient on the air side is calculated as in the steady-state [1,3-6]. The steady-state temperature distribution in fins is used to calculate the equivalent heat transfer. This simplification can lead to some errors, especially for higher fins.

The system of the governing differential equations is solved by the Laplace transform or the finite difference method. The Laplace transform method is widely used by Roetzel and Xuan [3] to model the transient operation of various heat exchangers. Taler [5] modeled the transient response of the PFTHE for a stepwise increase in liquid or gas temperature using the Laplace transform method. The transient temperature of the fluids was compared with temperature obtained by the finite volume method.

Korzeń and Taler [1] developed a new mathematical model of the PFTHE to simulate its transient operation. In contrast to the existing methods for the modeling transient response of heat exchangers with extended surfaces, in which the weighted steady-state heat transfer coefficient on the finned tube side is used, the transient temperature distribution will be calculated in each fin. This allows for computing more exactly the heat flow rate from the fins to the flowing gas.

Usually, modeling PFTHEs assumed that the fluid flow inside the tubes is turbulent. However, many low-duty heat exchangers operate in the transitional region when the Reynolds number varies in the range of 2 300 to about 12 000.

In this paper, numerical modeling of transient work of a PFTHE for low Reynolds numbers on the liquid side will be carried out.

2 Mathematical formulation of the problem

The system of partial differential equations describing the space and time changes of liquid T_1 , tube wall T_w , and air T_2 temperatures in one-row plate-fin and tube heat exchanger are [1]:

- liquid

$$\frac{1}{N_1} \frac{\partial T_1}{\partial x^+} + \tau_1 \frac{\partial T_1}{\partial t} = -(T_1 - T_w) \quad (1)$$

- tube wall

$$U_m \delta_w \rho_w c_w \frac{\partial T_w}{\partial t} + \frac{m_f c_f}{s} \frac{\partial \bar{T}_f}{\partial t} = \frac{k_w U_m \delta_w}{L_{ch}^2} \frac{\partial^2 T_w}{\partial (x^+)^2} + h_w U_{in} (T_1 - T_w) + h_o U_{bo} (\bar{T}_2 - T_w) \quad (2)$$

- air

$$\frac{1}{N_2} \frac{\partial T_2}{\partial y^+} + \tau_2 \frac{\partial T_2}{\partial t} = T_w - T_2 \quad (3)$$

where $\bar{T}_2$ denotes the mean air temperature over the row thickness, defined as

$$\bar{T}_2(x^+, t) = \int_0^1 T_2(x^+, y^+, t) dy^+ \quad (4)$$

The symbols $x^+ = x/L_{ch}$ and $y^+ = y/p_2$ in equations (1-3) stand for dimensionless coordinates. The numbers of heat transfer units N_1 and N_2 are given by

$$N_1 = \frac{h_1 A_{in}}{\dot{m}_1 c_{p1}}, \quad N_2 = \frac{h_2 A_{bo}}{\dot{m}_2 c_{p2}} \quad (5)$$

where: $s = L_{ch}/n_f$, $A_{in} = n_r U_{in} L_{ch}$, $A_{bo} = n_r U_{bo} L_{ch}$.

The time constants τ_1 and τ_2 are

$$\tau_1 = \frac{m_1 c_{p1}}{h_1 A_{in}}, \quad \tau_2 = \frac{m_2 c_{p2}}{h_2 A_{bo}}. \quad (6)$$

The symbols in equations (1-6) denote:

$$m_1 = n_r A_{in} L_{ch} \rho_1, \quad m_2 = n_r (p_1 p_2 - A_{oval}) (s - \delta_f) n_f \rho_2, \quad m_w = n_r U_m \delta_w L_{ch} \rho_w$$

$$m_f = (p_1 p_2 - A_{oval}) \delta_f \rho_w, \quad A_{in} = \pi a b, \quad A_{oval} = \pi (a + \delta_w) (b + \delta_w), \quad U_m = (U_{in} + U_{bo})/2.$$

The subscript w refers to the wall, f to the fin, and m to the mean value.

The weighted heat transfer coefficient h_o is defined by

$$h_o(t) = h_2(t) \left[\frac{A_{bbf}}{A_{bo}} + \frac{A_f}{A_{bo}} \cdot \eta_f(h_2, t) \right] \quad (7)$$

The initial temperatures of both fluids are equal and amount to T_0 . The initial conditions are

$$T_1(x^+, t) \Big|_{t=0} = T_{1,0}(x^+) \quad (8)$$

$$T_w(x^+, t) \Big|_{t=0} = T_{w,0}(x^+) \quad (9)$$

$$T_2(x^+, y^+, t) \Big|_{t=0} = T_{2,0}(x^+, y^+) \quad (10)$$

The boundary conditions have the following form

$$T_1(x^+, t) \Big|_{x^+=0} = f_1(t) \quad (11)$$

$$T_2(x^+, y^+, t) \Big|_{y^+=0} = f_2(t) \quad (12)$$

$$\frac{\partial T_w}{\partial x} \Big|_{x=0} = 0 \quad (13)$$

$$\frac{\partial T_w}{\partial x} \Big|_{x=L_{ch}} = 0 \quad (14)$$

where $f_1(t)$ and $f_2(t)$ are functions of time describing the variation of the liquid and air temperature at the inlets to the exchanger.

Fig. 1. Scheme of the one-row heat exchanger (a) and control volume (b).

The fin efficiency appearing in the relationship (7) was calculated using the Finite Volume Method based on the Finite Element Method. The division of the fin into finite volumes with the number of nodes is shown in Fig. 2.

The initial-boundary value problem defined by equations (1-14) applies to heat exchangers made of bare or finned tubes. For bare tubes m_f is equal to zero because there are no fins.

The transient temperature of the fluids and tube wall in the one-row heat exchanger (Fig. 1) were determined by the explicit finite difference method. To calculate time-dependent efficiency η_f of the rectangular fin attached to an oval tube the finite volume – finite element method (FVM-FEM) was used. Based on the mathematical model of the one-row heat exchanger, a mathematical model of the whole heat exchanger with a complex flow system was built.

The automotive radiator for the spark-ignition combustion engine with a capacity of 1580 cm³ is a double-row, two-pass plate-finned heat exchanger. The radiator consists of aluminium tubes of oval cross-section. The cooling liquid flows in parallel through both tube rows.

Fig. 2. Division of the fin model into finite volumes with node numbers.

3 Experimental correlations for Nusselt numbers at water and air side

In the developed mathematical model of the exchanger, the heat transfer coefficients on the air and water side are calculated from experimental correlations. The correlations for the heat transfer coefficient were derived assuming a fully developed turbulent flow in straight tubes. One of the most common correlations is the Dittus-Boelter formula [7-9]:

$$Nu_w = 0,023 Re_w^{0,8} Pr_w^n \left[1 + \left(\frac{d_r}{L_{ch}} \right)^{2/3} \right]. \quad (15)$$

where $n = 0.4$ when the fluid is heated and $n = 0.3$ when it is cooled. In recent years, the Gnielinski correlation is becoming more and more popular [10-11].

$$Nu_w = \frac{(\xi/8)(Re_w - 1000)Pr_w}{(1 + 12,7\sqrt{(\xi/8)}(Pr_w^{2/3} - 1))} \left[1 + \left(\frac{d_r}{L_{ch}} \right)^{2/3} \right], \quad (16)$$

where the friction loss coefficient ξ is defined as:

$$\xi = \frac{1}{(1,82 \log Re_w - 1,64)^2} = \frac{1}{(0,79 \ln Re_w - 1,64)^2}. \quad (17)$$

In Formula (16), symbols d_r and L_{ch} denote the tube hydraulic diameter and length, respectively. The reason for the growing popularity of the Gnielinski formula (16) is its greater accuracy in the transition area of $2300 < Re_w < 10000$. Despite the fact that the Gnielinski proposal gives smaller values of the heat transfer coefficient in the transition area compared to the Dittus-Boelter formula, these values are still inflated [12-13]. If $Re_w < 2300$, the flow is laminar; the Nusselt number is $Nu_w = 4.364$ and does not depend on the Reynolds number [7-8]. It can be checked easily that both the Dittus-Boelter and the Gnielinski formulae give values of Nuc much higher than 4.364. For this reason, the correlations for the Nusselt numbers on the water and air side were determined based on experimental testing.

The following form of the correlation for the Nusselt number at the air side was taken:

$$Nu_a = x_1 Re_a^{x_2} Pr_a^{1/3}. \quad (18)$$

Considering that the range of changes in the Reynolds number at the air side is not too big, it is possible to approximate experimental data well using the exponential equation written above (18).

The correlation for the Nusselt number at the water side was taken in a form similar to the formulae developed by Petukhov and Kirillov [14] and Gnielinski [10].

$$Nu_w = \frac{(\xi/8)(Re_w - x_3)Pr_w}{(1 + x_4\sqrt{(\xi/8)}(Pr_w^{2/3} - 1))} \left[1 + \left(\frac{d_r}{L_{ch}} \right)^{2/3} \right] \quad (19)$$

The values of coefficients $x_1, x_2, \dots, x_m$ will be selected so that the sum of the squares of differences in temperature

$$S = \sum_{i=1}^n \left[f''_{w,i} - T''_{w,i} (x_1, \dots, x_m) \right]^2 = \min \quad (20)$$

$$f''_{w,i} = T'_{w,i} - \Delta T_{w,i} \quad (21)$$

should reach the minimum.

The real values of the determined parameters $\tilde{x}_1, \dots, \tilde{x}_m$ are included with probability $P = (1 - \alpha) \cdot 100$ [%] in the following intervals [15-16]:

$$x_i - t_{n-m}^{\alpha/2} \cdot s_i \sqrt{c_{ii}} \leq \tilde{x}_i \leq x_i + t_{n-m}^{\alpha/2} \cdot s_i \sqrt{c_{ii}}, \quad (22)$$

where

x_i – parameter value determined by means of the least squares method,

$t_{n-m}^{\alpha/2}$ – t -Student distribution quantile for the confidence level $1 - \alpha$ and $n - m$ degrees of freedom.

Quantity s_i^2 is the variance estimate calculated from:

$$s_i^2 = \frac{\sum_{i=1}^n \left[T''_{w,i} (x_1, \dots, x_m) - f''_{w,i} \right]^2}{n - m} = \frac{S(\tilde{x}_1, \dots, \tilde{x}_m)}{n - m}. \quad (23)$$

Where n – number of measuring points and m – number of sought parameters.

Quantities c_{ii} are diagonal elements c_{ii} of the covariance matrix.

In this case, the number of measuring points is $n = 47$, and the number of unknown parameters is $m = 4$.

3.1 Experimental correlations

The thermal and flow measurements of the exchanger were performed for different air and water flow velocities. The measurement results are presented in [17].

The Reynolds number values at the air side: $Re_a = w_{\max} d_h / \nu_a$ and at the water side: $Re_{wg} = w_{wg} d_r / \nu_w$. The air physical properties were calculated at the air average temperature. Similarly, the thermophysical properties of water were calculated at the average temperature. The average temperature is understood as the arithmetic mean of the average temperature at the exchanger inlet and outlet. The water velocity in the upper pass w_{wg} is smaller than the water velocity in the lower pass w_{wd} because in the upper pass water flows in parallel through 20 tubes whereas in the lower one – through 18.

Based on the data presented in Table 1, the following values of individual coefficients were obtained:

$$x_1 = 0,0713 \pm 0,0053; x_2 = 0,7055 \pm 0,0136; x_3 = 0,4624 \pm 0,3194; x_4 = 22,2273 \pm 0,3163$$

The coefficients are present in Formulae (18) and (19).

The value of the sum of squares: $S = 1.07041 \text{ K}^2$.

The correlations for the Nusselt numbers on the water and air side have the following form:

$$Nu_a = 0,0713 Re_a^{0,7055} Pr_a^{1/3}, \quad 60 \leq Re_a \leq 351 \quad (24)$$

$$Nu_w = \frac{(\xi/8)(Re_w - 0,4624)Pr_w}{(1 + 22,2273\sqrt{(\xi/8)(Pr_w^{2/3} - 1)})} \left[1 + \left(\frac{d_r}{L_{ch}} \right)^{2/3} \right], \quad 3850 \leq Re_w \leq 11317 \quad (25)$$

In the mathematical model of the radiator operation under unsteady-state conditions the relationships (24) and (25) were used.

3.2 Increase in water mass flow in time

The comparison of the results obtained from measurements and calculations is presented in Fig. 3.

Fig. 3. The exchanger unsteady-state operation caused by a sudden reduction in the water volume flow;

- 1 – $\dot{V}'_w$ – water volume flow at the exchanger inlet, l/s
- 2 – T'_{am} – average air temperature before the exchanger, °C
- 3 – T''_{am} – average air temperature after the exchanger, °C
- 4 – T'_w – water temperature before the exchanger, °C
- 5 – T''_w – water temperature after the exchanger, °C
- 6 – w_0 – air velocity before the exchanger, m/s
- 7 – T''_w – calculated water temperature after the exchanger, °C
- 8 – T''_{am} – calculated average air temperature after the exchanger, °C.

The increase in the water volume flow causes a rise in the water and air temperatures at the exchanger outlet (Fig. 3). The increment in the air temperature is bigger than the increment in the water temperature. This results from the smaller flux of the air heat capacity $\dot{m}_a c_{pa}$ compared to the heat capacity flux of water $\dot{m}_w c_w$. If the heat flux given up by water is the same as the one absorbed by air, the increment in the air temperature is higher.

Fig. 4 presents changes in the water and the tube wall temperatures on the exchanger length in time $t = 119$ s (Fig. 3).

Fig. 4. Distribution of the water and the tube wall temperatures on the exchanger length for time $t = 119$ s in the steady state.

Analysing the results presented in Fig. 4, it can be seen that water in the first row tubes cools down more than in the tubes placed in the second row. This concerns both the upper and lower pass. It can be noticed that the tube wall temperature is lower than the water temperature due to the fact that heat is absorbed by cold air.

Fig. 5. Changes in the fin base temperature T_b and the fin temperature in 12 nodes, that are marked in Fig. 2, at a distance of 247 mm (9.5 cell lengths) from each pass inlet:
(a) – first tube row in the first (upper) pass, (b) – second tube row in the first (upper) pass,
(c) – first tube row in the second (lower) pass, (d) – second tube row in the second (lower) pass.

The curves illustrating time-dependent changes in the temperature of selected fins are presented in Fig. 5a – d. An analysis of the results indicates that the highest temperature is at the fin base, and the lowest in node 3 (Fig.2), which is the most distant from the tube axis. It can be seen that the temperatures of the fins in the first tube row (Fig. 5a and 5c) are lower than in the second row (Fig. 5b and 5d). Cold inflowing air cools the fins and tubes located in the first row better. The air temperature after the first tube row is much higher compared to the inlet air temperature. Due to a reduction in the difference between the temperatures of the flowing air and the tubes located in the second row, the temperature of the water and fins in the second tube row is higher than in the first row.

4 Conclusions

The calculations and measurements carried out in the paper confirm that the developed numerical model of the plate fin and tube heat exchanger has a high accuracy. This model is particularly useful to simulate exchanger, where the temperature of the fins can be very high. Thanks to the experimental determination of heat transfer correlations on the air and water sides a very good agreement of calculations and measurements was reached. The developed model can be used to simulate the heating and cooling heat exchanger and in automatic control systems.

References

1. Korzeń A., Taler D.: Modeling of transient response of a plate fin and tube heat exchanger, *Int. J. Therm. Sci.*, **92** (2015), pp.188-198.
2. Taler D.: Mathematical modeling and control of plate fin and tube heat, *Energy conversion and management*, **96** (2015), pp. 452-462.
3. Roetzel W., Xuan Y.: *Dynamic behaviour of heat exchangers*, *Computational Mechanics Publications Vol.3*, WIT Press, Southampton 1998.
4. Ataer Ö.E.: An approximate method for transient behavior of finned-tube cross-flow heat exchangers, *Int. J. Refrig.*, **27** (2004), pp. 529-539.
5. Taler D.: *Direct and inverse heat transfer problems in dynamics of plate fin and tube heat exchangers*. in: Belmiloudi A. (ed.) *Heat transfer, mathematical modelling, numerical methods and information technology*, InTech, Rijeka 2011, pp 77–100, free online edition: www.intechopen.com.
6. Vaisi A., Talebi S., Esmailpour M.: *International Communications in Heat and Mass Transfer*, **38** (2011), pp. 951-957.
7. Arpaci V. S., Kao S. H., Selamet A.: *Introduction to Heat Transfer*, Prentice Hall, Upper Saddle River, NJ, USA 1999.
8. Bejan A., Kraus A. D., Ed.: *Heat Transfer Handbook*, John Wiley & Sons, Inc., Hoboken, New Jersey 2003.
9. Wiśniewski S, Wiśniewski T. S.: *Wymiana ciepła (Heat exchange)*, Wydanie 6, WNT, Warszawa 2009.
10. Gnielinski V.: Neue Gleichungen für den Wärme- und den Stoffübergang in turbulent durchströmten Rohren und Kanälen, *Forschung im Ingenieurwesen*, 41 (1975) Nr.1, S. 8-16
11. Webb R. L.: *Principles of enhanced heat transfer*, John Wiley & Sons, Inc., Hoboken, New Jersey 1994.
12. Mirth D. R., Ramadhyani S., Hittle D. C.: Thermal performance of chilled-water cooling coils operating at low water velocities. *ASHRAE Transactions*, Vol. 99 (1993), Part 1, pp. 43-53.
13. Mirth D. R., Ramadhyani S.: Correlations for predicting the air side Nusselt numbers and friction factors in chilled-water cooling coils. *Experimental Heat Transfer*, Vol. 7 (1994), pp. 143-162.
14. Petukhov B.S., Genin A.G., Kovalev S.A.: *Heat transfer in nuclear power plants*. Atomizdat, Moscow 1974 (in Russian).
15. Brandt S.: *Data Analysis. Statistical and computational methods for scientists and engineers*, 3rd edn. Springer, Berlin 1999.
16. Coleman H.W., Steele W.G.: *Experimentation, validation, and uncertainty analysis for engineers*, 3rd edn. Wiley, Hoboken 2009.
17. Korzeń A.: *Mathematical modelling of the operation of cross-flow finned-tube heat exchangers*, Wydawnictwo Politechniki Krakowskiej, Kraków 2015.