A Modified Activated Sludge Model No.3 (ASM3) for Membrane Bioreactor (MBR) with an Emphasis for Solids Hydrolysis

Xinyue Jiang*, Bin Xu

School of Environmental Engineering and Science, Yangzhou University, Yangzhou. People's Republic of China

Abstract. The previously assumed “inert” organics measured by respirometric method has been reported to be hydrolysable under long sludge retention time (SRT) configuration such as membrane bioreactor (MBR). The sludge production under long SRT has also shown to be lower than the standard activated sludge model (ASM) prediction. The hydrolysis of “inert” organics can provide the extra carbon source for denitrification. The current modeling approach has not yet included this aspect. In this study, a modified ASM3 was developed to account for the hydrolysis of “inert” organics and subsequent effect on the denitrification process under long SRT.

1 Introduction

The ASM family (ASM1, 2, 2D, 3) is designed for conventional activated sludge (CAS) wastewater treatment system with lower and upper SRT limit of 3 and 30 days[1]. The MBR usually features high SRT, high mixed liquor concentration[2]. Therefore the migration of ASM developed for CAS process to MBR system usually requires the modification of the original model. The modification usually related to the change of parameter values or the model framework by adding more processes and state variables[3].

The high SRT in MBR also challenged the conventional respirometric method in determining the slowly biodegradable COD (X_S) and inert COD (X_I)[4]. The respirometric method was usually carried out in short term; therefore a large part of slowly hydrolysable organics (X_{SH}) was included in the X_I fraction. Under long SRT, a significant part of the “inert” organics (X_I) can actually be hydrolyzed[3]. The application of ASM originally developed for CAS in MBR results in the overestimation of sludge production.

The modified ASMs for MBR are mainly for the estimation of sludge production[5]. It is not clear how the hydrolysis of “inert” organics (X_I) affect the denitrification process. The shortage of readily biodegradable COD (S_S) is usually a major limitation of the denitrification step in biological nutrient removal (BNR) process. Theoretically, the extra S_S from the “inert” organics hydrolysis can increase the carbon source available for denitrification. In this study, a modified ASM3 was developed to account for the hydrolysis of X_I and subsequent effect on the

denitrification process under long SRT. The ASM3 was chosen because it includes a storage process, which was commonly observed in MBR with post-denitrification configuration[6][7], in which the stored carbon source (X_{STO}) was assumed to be the major electron donor for denitrification.

2 Model development and implementation

2.1 The hydrolysis of slowly hydrolysable solids (X_{SH})

A new state variable X_{SH} was introduced that included the X_I fraction and the inert solids from endogenous decay (X_P). The hydrolysis of X_{SH} was assumed to be first order kinetics following recommendation from Lubello et al. [5]:

$$\frac{dX_{SH}}{dt} = -k_{SH} X_{SH} \quad (1)$$

Where, k_{SH} was the hydrolysis rate, with a default value of 0.012d^{-1} .

A complete stoichiometric matrix and kinetic rates of the modified ASM3 model could be found in Table.1 and Table.2. The definition of symbols and parameter values could be found in [1].

* Corresponding author: xinyuej@126.com

Table.1 Stoichiometric matrix of the modified ASM3 model

Components		1	2	3	4	5	6	7	8	9	10	11
Process		S_{O_2}	S_I	SS	S_{NH_4}	S_{NOX}	S_{ALK}	X_{SH}	X_S	X_H	X_A	X_{STO}
1	Hydrolysis of X_S		f_{SI}	$1-f_{SI}$	$i_{N,XS}-i_{N,SS}(1-f_{SI})-f_{SI} i_{N,SI}$		$[i_{N,XS}-i_{N,SS}(1-f_{SI})-f_{SI} i_{N,SI}]/14$		-1			
2	Hydrolysis of X_{SH}		f_{SI}	$1-f_{SI}$	$i_{N,XS}-i_{N,SS}(1-f_{SI})-f_{SI} i_{N,SI}$		$[i_{N,XS}-i_{N,SS}(1-f_{SI})-f_{SI} i_{N,SI}]/14$	-1				
3	Aerobic storage of S_S	$Y_{STO,O_2}-1$		-1	$i_{N,SS}$		$i_{N,SS}/14$					Y_{STO,O_2}
4	Anoxic storage of S_S			-1	$i_{N,SS}$	$(Y_{STO,NOX}-1)/2.86$	$[i_{N,SS}-(Y_{STO,NOX}-1)/2.86]/14$					$Y_{STO,NOX}$
5	Aerobic growth of X_H	$1-1/Y_{H,O_2}$			$-i_{N,BM}$		$-i_{N,BM}/14$			1		$-1/Y_{H,O_2}$
6	Anoxic growth of X_H				$-i_{N,BM}$	$(1-1/Y_{H,NOX})/2.86$	$[-i_{N,BM}-(Y_{H,NOX}-1)/2.86]/14$			1		$-1/Y_{H,NOX}$
7	Aerobic endog. Respiration of X_H	$f_{SH}-1$			$i_{N,BM}-f_{SH}i_{N,XSH}$		$(-i_{N,BM}-f_{SH}i_{N,XSH})/14$	f_{SH}		-1		
8	Anoxic endog. Respiration of X_H				$i_{N,BM}-f_{SH}i_{N,XSH}$	$(f_{SH}-1)/2.86$	$[i_{N,BM}-f_{SH}i_{N,XSH}-(f_{SH}-1)/2.86]/14$	f_{SH}		-1		
9	Aerobic respiration of X_{STO}	-1										-1
10	Anoxic respiration of X_{STO}					-1/2.86	$1/2.86/14$					-1
11	Aerobic growth of X_A	$1-4.57/Y_A$			$-i_{N,BM}-1/Y_A$	$1/Y_A$	$-1/7Y_A-i_{N,BM}/14$				1	
12	Aerobic endog. Respiration of X_A	$f_{SH}-1$			$i_{N,BM}-f_{SH}i_{N,XSH}$		$(i_{N,BM}-f_{SH}i_{N,XSH})/14$	f_{SH}			-1	
13	Anoxic endog. Respiration of X_A				$i_{N,BM}-f_{SH}i_{N,XSH}$	$(f_{SH}-1)/2.86$	$[i_{N,BM}-f_{SH}i_{N,XSH}-(f_{SH}-1)/2.86]/14$	f_{SH}			-1	

Table 2. Kinetic rates for the modified ASM3 model

j	Processes	Process rate R _j
1	Hydrolysis of X_S	$R_1 = k_H \frac{X_S / X_H}{K_X + X_S / X_H} X_H$
2	Hydrolysis of X_{SH}	$R_2 = k_{SH} X_{SH}$
3	Aerobic storage of S_S	$R_3 = k_{STO} \frac{S_{O_2}}{K_{O_2} + S_{O_2}} \frac{S_S}{K_S + S_S} X_H$
4	Anoxic storage of S_S	$R_4 = k_{STO} \eta_{NO_x} \frac{K_{O_2}}{K_{O_2} + S_{O_2}} \frac{S_{NO_x}}{K_{NO_x} + S_{NO_x}} \frac{S_S}{K_S + S_S} X_H$
5	Aerobic growth of X_H	$R_5 = \mu_H \frac{S_{O_2}}{K_{O_2} + S_{O_2}} \frac{S_{NH}}{K_{NH} + S_{NH}} \frac{S_{ALK}}{K_{ALK} + S_{ALK}} \frac{X_{STO} / X_H}{K_{STO} + (X_{STO} / X_H)} X_H$
6	Anoxic growth of X_H	$R_6 = \mu_H \eta_{NO_x} \frac{K_{O_2}}{K_{O_2} + S_{O_2}} \frac{S_{NH}}{K_{NH} + S_{NH}} \frac{S_{ALK}}{K_{ALK} + S_{ALK}} \frac{X_{STO} / X_H}{K_{STO} + (X_{STO} / X_H)} X_H$
7	Aerobic endog. Respiration of X_H	$R_7 = b_{H,O_2} \frac{S_{O_2}}{K_{O_2} + S_{O_2}} X_H$
8	Anoxic endog. Respiration of X_H	$R_8 = b_{H,NO_x} \frac{K_{O_2}}{K_{O_2} + S_{O_2}} \frac{S_{NO_x}}{K_{NO_x} + S_{NO_x}} X_H$
9	Aerobic respiration of X_{STO}	$R_9 = b_{H,O_2} \frac{S_{O_2}}{K_{O_2} + S_{O_2}} X_{STO}$
10	Anoxic respiration of X_{STO}	$R_{10} = b_{H,NO_x} \frac{K_{O_2}}{K_{O_2} + S_{O_2}} \frac{S_{NO_x}}{K_{NO_x} + S_{NO_x}} X_{STO}$
11	Aerobic growth of X_A	$R_{11} = \mu_A \frac{S_{O_2}}{K_{A,O_2} + S_{O_2}} \frac{S_{NH}}{K_{A,NH} + S_{NH}} \frac{S_{ALK}}{K_{A,ALK} + S_{ALK}} X_A$
12	Aerobic endog. Respiration of X_A	$R_{12} = b_{A,O_2} \frac{S_{O_2}}{K_{A,O_2} + S_{O_2}} X_A$
13	Anoxic endog. Respiration of X_A	$R_{13} = b_{A,NO_x} \frac{K_{A,O_2}}{K_{A,O_2} + S_{O_2}} \frac{S_{NO_x}}{K_{A,NO_x} + S_{NO_x}} X_A$

2.2 Model configuration

Both modified and standard ASM3 were configured to be applied in a post-denitrification MBR process shown in Fig.1.

Fig.1. Plant configuration of a post-denitrification MBR

The average hydraulic retention time (HRT) for the whole plant was 12 h. With the average influent flow rate of 18446 m³/d (Table.3), the total volume of aerobic (V_{AE}) and anoxic tank (V_{AX}) could be calculated to be 9223 m³. The V_{AE} / V_{AX} ratio was chosen to be 50/50%[8]. The total SRT was set to be within 10-90 days by adjusting the wasted sludge flow rate (Q_W). The return sludge flow rate (Q_R) from anoxic tank to aerobic tank was set to be 50% of the average influent flow rate.

Table.3. The flow-weighted average influent concentration

Symbol	Value
S_I	30
S_S	69.5
S_{NH4}	38.51
S_{NOX}	0
S_{ALK}	7
$X_{SH}(X_I)$	51.20
X_S	202.32
X_H	28.17

X_A	0
X_{STO}	0
Q	18446m ³ /d

The mass balance equation for the aerobic tank could be written by the following equations:

$$V_{AE} \frac{dS_{AE}}{dt} = Q_{in}S_{in} + Q_R S_{AX} - (Q_{in} + Q_R)S_{AE} + r_{AE}^S V_{AE} \quad (2)$$

$$V_{AE} \frac{dX_{AE}}{dt} = Q_{in}X_{in} + Q_R X_{AX} - (Q_{in} + Q_R)X_{AE} + r_{AE}^X V_{AE} \quad (3)$$

Where, S_{AE} , X_{AE} represent the soluble and solid component concentration in the aerobic tank; r_{AE}^S and r_{AE}^X were the reaction rate of the soluble and solid component respectively, which could be calculated from the stoichiometric matrix and kinetic rates in Table.1 and Table.2.

Similarly, the mass balance equations for the anoxic tank were:

$$V_{AX} \frac{dS_{AX}}{dt} = (Q_{in} + Q_R)(S_{AE} - S_{AX}) + r_{AX}^S V_{AX} \quad (4)$$

$$V_{AX} \frac{dX_{AX}}{dt} = (Q_{in} + Q_R)X_{AE} - (Q_R + Q_W)X_{AX} + r_{AX}^X V_{AX} \quad (5)$$

Where, S_{AX} , X_{AX} represent the soluble and solid component concentration in the aerobic tank; r_{AX}^S and r_{AX}^X are the reaction rate of the soluble and solid component.

2.3 Model implementation

The “dry weather” influent data from the benchmark configuration was used to compare the modified ASM with the standard ASM3[9][10]. The benchmark influent data was available in 14 days with 15 minutes interval. The variation in influent flow rate and concentration

made the simulation in an unsteady condition. To eliminate the influence of initial conditions on the modeling results, the steady state was derived by simulating 100 days using the flow-weighted average influent data (Table.3). The steady state solved this way was regarded as the initial condition for the following dynamic modeling.

Since the influent file was made for the ASM1, some modifications were needed to use it in the ASM3 model. The soluble biodegradable nitrogen (S_{ND}) in the benchmark data was included in the NH_4^+ (S_{NH}) as the ammonification process was assumed to be fast and removed in ASM3. The particulate biodegradable nitrogen (X_{ND}) was omitted as it was included in other solids components.

3. Modeling results

3.1 Comparison with no hydrolysis

Fig.2 showed the comparison of nitrogen removal and solids concentration between the modified and standard ASM3 at SRT of 40 d. With the hydrolysis of X_{SH} included in the modified model, a lower 5.5g/L X_{SH} was predicted, as compared to the 7g/L for the standard ASM3. Correspondingly, the S_{NOX} concentration in the modified ASM3 prediction was lower than the standard ASM3, suggesting higher denitrification efficiency due to the extra carbon source from the X_{SH} hydrolysis. The carbon storage (X_{STO}) and heterotrophic biomass concentration (X_H) are also higher in the modified ASM3 prediction than the standard ASM3 prediction.

Fig.2. Comparison of nitrogen removal and solids concentration between the modified and standard ASM3.

3.2 Effect of SRT on the availability of carbon source for denitrification

The carbon source used for de-nitrification in the ASM3 framework was assumed from the consumption of carbon storage (X_{STO}). The anoxic growth of heterotrophic biomass (X_H) on the carbon storage (X_{STO}) results in the denitrification of S_{NOX} . The total carbon source consumed for denitrification ($C_{X_{sto} \rightarrow D}$, mg/L) in the 14 days simulation can be calculated from the following equation:

$$C_{X_{sto} \rightarrow D} = \int_0^{14} \frac{R_6}{Y_{H,NOX}} dt \quad (6)$$

Where, R_6 (mgL⁻¹d⁻¹) was the heterotrophic biomass (X_H) anoxic growth rate (Table.2); $Y_{H,NOX}$ was the anoxic yield of heterotrophic biomass (X_H).

The percentage of extra carbon source used for denitrification due to hydrolysis of X_{SH} can be calculated

by:

$$P_{SH} = \frac{C_{X_{sto} \rightarrow D}^h - C_{X_{sto} \rightarrow D}^{nh}}{C_{X_{sto} \rightarrow D}^h} 100\% \quad (7)$$

Where, $C_{X_{sto} \rightarrow D}^h$ was the total carbon source consumed for denitrification calculated from equation 0, including the X_{SH} hydrolysis process; $C_{X_{sto} \rightarrow D}^{nh}$ was the equivalent without the X_{SH} hydrolysis process.

Fig.3(1) showed that the amount of carbon source used for denitrification ($C_{X_{sto} \rightarrow D}$) increased with SRT. The increasing scope was much higher when the hydrolysis of X_{SH} was included. Without the carbon source from the hydrolysis of X_{SH} , the $C_{X_{sto} \rightarrow D}$ value maintained around 4.6 g/L when the SRT was between 50-90 days. Fig.3(2) indicated that an extra of 2-10% of carbon source was used in denitrification due to the hydrolysis of X_{SH} .

Fig.3. Carbon source used for denitrification under different SRT

3.3 Sludge production under different SRT

The standard ASM developed for CAS used in long SRT MBR overestimated the sludge production[3]. By including a hydrolysis process for the slowly hydrolysable X_{SH} , Lubello et al.[5] reported satisfactory sludge production estimation with hydrolysis kinetic rate K_{SH} of 0.012d⁻¹. Fig.4(1) showed that the modified ASM3 predicted a significant lower sludge production compared

to the standard ASM3. Pollice et al.[11] reported sludge production of a MBR treating municipal wastewater at SRT of 20, 40, 60 and 80 d. By normalizing the sludge production to the SRT=20 d value and comparing to the predicted sludge production by the modified and standard ASM3 (Fig.4(2)), it could be found that the modified ASM3 showed a better match to the Pollice's[11] sludge production data. This suggested that the K_{SH} value of 0.012d⁻¹ might be meaningful.

Fig.4. Sludge production under different SRT

3.4 Effect of hydrolysis rate on the model prediction results

It should be noted that the K_{SH} value of $0.012d^{-1}$ from Lubello et al.[5] was derived from experiment on tannery wastewater. It might not be the same for domestic sewage. Fig.5 showed the effluent S_{NOX} and X_{SH} in the mixed liquor prediction by the modified ASM3 under different K_{SH} value. It can be seen that de-nitrification

efficiency was greater for high value and a significant low X_{SH} was predicted.

Fig.5 was derived by simulating the modified ASM3 model under different K_{SH} value with other parameters kept the same. Some of the parameters for the long SRT MBR configuration might need to be altered, which might contradict or further enhance the trend shown in Fig.5. More experiment validation of the modified ASM3 is needed.

Fig.5. Effect of hydrolysis rate on the model prediction results

4. Conclusion

A modified ASM3 model was proposed that included the hydrolysis of previously assumed “inert” organics. The simulation of the modified ASM3 model on post-denitrification MBR indicated that more carbon source was available for denitrification from the hydrolysis of X_{SH} . A lower sludge production was also predicted by the modified ASM3 model.

References:

1. M.Henze, et al., *Activated Sludge Models ASM1, ASM2, ASM2d, and ASM3*. IWA Scientific and Technical Report No. 9.IWA Publishing, London, UK. (2000)
2. S. Judd, *The MBR Book*, Oxford. Elsevier Science (2006)
3. A.Fenu, et al., *Water Res.*, **44**(15),4272-4294 (2010)
4. G.A.Ekama, P.L. Dold, and G.v.R. Marais, *Wat. Sci. Tech.*,**18**(6),91-114 (1986)
5. C.Lubello, et al., *Water Res.*,**43**(18),4539-4548(2009)
6. M.Vocks, et al., *Water Res.*, **39**(14),3360-3368(2005)
7. M.Winkler, E.R. Coats, and C.K. Brinkman, *Water Res.*, **45**(18),6119-6130 (2011)

8. J.Pinnekamp, *Municipal Water and Waste Management:Membrane Technology for Waste Water Treatment*. FIW Verlag, Aachen (2006)
9. J.B.Copp, *The COST Simulation Benchmark: Description and Simulator Manual*.Office for Official Publications of the European Communities, Luxembourg (2002)
10. I.Iacopozzi, et al., *Environ. Model. Softw.*, **22**(6),847-861 (2007)
11. A.Pollice, Laera, G., Saturno, D., Giordano, C., *J. Membr. Sci.*, 317(1-2), 65-70 (2008)