Model predictive control of heat pump based on a regression model fitted to data measured in accordance to EHPA regulation

Simon Thorsteinsson^{1*}, Søren Østergaard Jensen² and Jan Dimon Bendtsen¹

¹Aalborg University, Department for Automation and Control, 9220 Aalborg Øst, Denmark

²Danish Energy Agency, Centre for Global Cooperation, 1577 Copenhagen, Denmark

Abstract. This paper presents a method for fitting a static regression model for the power consumption of a ground-sourced domestic heat pump, based on a low number of sample points extracted from a common measurement report developed in accordance to European Heat Pump Association (EHPA) regulation. Thereafter, we demonstrate how the coefficients can be updated with a *Recursive Least Squares* algorithm using only commonly accessible measurements. The regression model is designed to be used for control of a heat pump connected to an ON/OFF controlled floor heating system. The target of the method is especially systems where the flow in the floor heating circuits is unknown. The ability of the regression model to predict power consumption of the heat pump is evaluated using measurements obtained from a test-rig having the particular heat pump installed. The regression model is implemented as a module in a *Mixed Integer Non-linear Model Predictive Control* algorithm to illustrate the applicability of the model for control purposes. The promising results obtained from this investigation raise the question; should quality data be available in order to enable more advanced control of domestic heat pumps?

1 Introduction

The later years have seen a large increase in electric heat pumps becoming the main source of heat in single-family houses [1]. This electrification of the heat source creates an interesting bridge between space heating and electricity consumption. A connection, which is particularly interesting, if more energy assets (solar panels, energy storages, domestic wind turbines, etc.) are connected to the same system. Such energy assets are not independent, in the sense that the operational mode of one affect the others and vice versa.

In that light, there is a wish for harvesting the full potential of energy optimization for the combined system by coordinating these energy assets instead of letting them operate according to own objectives. Further, other external factors can be taken into account such as weather, resident behaviour, energy prices.

To optimize the operation with respect to energy savings, the controller must have knowledge about the system and environment and continuously collect measurements during operation in order to make optimal decisions regarding when, where and how much to heat.

Among other methods, such as *Neural Networks* (NN), *Machine Learning* (ML) and other *Artificial Intelligence* methods, *Model Predictive Control* (MPC) has been shown to be a solution to such a control problem. In [2] linear, linear time-varying and non-linear MPC are applied to control an air-to-water heat pump connected to radiant floor heating. The performance of the heat pump is modelled using a time

dependent function. The authors in [3] controlled a solar assisted heat pump using MPC with the heat pump efficiency modelled using a piece-wise linear function.

In this work we focus on the model of a domestic ground-sourced heat pump as a component in an MPC control scheme. More specifically, the model is a static regression expression with linear coefficients. The method presented here is developed with three goals in mind. The inputs to the model are restricted to be control inputs and cheap to measure state variables. Second, only readily available data can be used for fitting the coefficients. Last, it is a requirement that the model takes part as module in a functioning MPC algorithm.

The reason for the restrictions on data and measurements is that MPC, as well as the other mentioned methods, in general suffers from high commissioning costs. It easily gets very expensive to either develop a model, which MPC relies on, or collect the necessary data for methods like ML and NN. Without extensive amounts of data ML and NN cannot identify the important connections between cause and effect in the system.

Until a solution is found most existing systems in single-family houses will likely either be regulated by ON/OFF- or PID-controllers.

We therefore ask whether it is possible to develop models and methods, which are cheap to obtain and perform acceptable.

To elaborate on the meaning of readily available data. It is common practice, for the manufacturer, to commission a measurement of the coefficient of

* Corresponding author: sith@es.aau.dk

performance (COP), seasonal coefficient of performance (SCOP) and other parameters according to the standards **DIN EN 14511** (COP) [4], **DIN EN 14825** (SCOP) [5], **DIN EN 16147** (Domestic hot water heat pumps) [6]. The data generated during these tests exists for most heat pumps, which means it holds the potential of becoming the foundation for a generalized method for obtaining the model fit.

The concept of fitting regression models to such standard measurements is not new, in [7] the authors, in similar fashion, fit regression models to catalogue data, provided by the manufactures, with a high degree of accuracy. In [8] different linear, non-linear regression and artificial neural networks models are compared. However, unlike the previous works, we aim specifically at using the model in MPC schemes.

The layout of the rest of the paper is; first, we describe the fit of the regression model. Thereafter, a *Recursive Least Squares* (RLS) algorithm is applied to update the coefficients using the measured input power of the heat pump.

To validate the heat pump model, we investigate the accuracy of the fit when compared to data obtained from a test-rig and implement the model into a *Mixed-Integer Non-linear* MPC example to prove that the model can be part of a solvable optimization problem.

In the end, we elaborate on the findings and potential issues. Further, we discuss the potential value of these measurement reports, being made according to requirements established by the European Heat Pump Association (EHPA), with respect to control, and ask whether such reports should be mandatory and publicly available.

2 Materials and Methods

In this section the system is presented, followed by the method for fitting and recursively updating the linear coefficients for the static regression model. At last the *Mixed Integer Non-linear Programming* (MINLP) *Model Predictive Control* (MPC) example is described.

2.1 Introduction to system

The system considered in this paper, seen in Figure 1, reflects a common installation found in many houses.

Figure 1. Overview diagram of system in scope [9].

The setup is a ground-sourced heat pump, which feeds M floor heating circuits with hot water. Each floor heating circuit provides heat to its own separate room. The flow of each floor heating circuit is balanced using a pre-set manifold valve and is controlled by an ON/OFF control valve. The control valves in a floor heating manifold are often wax-motor driven, which means there is a delay between the control signal and the reaction of the valve. In this work, we assume the reaction to be instantaneous. Table 1 shows signals and measurements that are available during operation.

Table 1. The available measurements and signals.

Symbol	Type	Description
P_{HP}	Sensor	Electric power input to HP
T_R	Sensor	Return temperature to HP
$T_{R,i}$	Sensor	Return Temperature i
$T_{r,i}$	Sensor	Room Temperature i
T_F	Ctrl. signal	Forward Temp. from HP
v_i	Ctrl. signal	Set-point of control valve i

The measurements have been limited to temperature and electric power, since they are measureable at low costs compared to e.g. measuring flow. There are $M + 1$ control signals; the forward temperature from the heat pump T_F and one valve state $v_i \in \{0,1\}$ for each of the M circuits. The valve state 0 corresponds to *OFF* and 1 to *ON*. Note that the forward temperature is common for all open circuits, which means it is necessary to choose a forward temperature, which fits all open circuits.

2.2 Data

This study is based upon two main datasets, which are presented in the following two subsections. All data is freely available for download at [10].

2.2.1 Standard test data

The smaller dataset consist of 18 sample points extracted from the report containing the measurements obtained according to the standards EN14500, EN14825, EN16147. This data is from henceforward referred as the *standard test data*.

Table 2. Overview of *standard test data*.

Symbol	Description	Unit
Q_{HP}	Heat produced by HP	[W]
P_{HP}	Electric power consumed by HP	[W]
q	Mass flow	[kg/s]
T_R	Return temperature to the HP	[°C]
T_F	Forward temperature from HP	[°C]
COP	Coefficient of performance	[-]

2.2.2 Test-rig data

The larger dataset consist of time series data sampled each minute over a time period of 24 days. The data is obtained from a test rig where the heat pump delivers heat to a simulated house with four floor heating circuits. The simulation calculates the response of the house based on the forward temperature and water flow.

A cooling system cools the return water from each circuit to emulate the transfer of heat to the floor. This dataset is divided into two parts. The first part covers 10 days and plays the role as data measured during operation, and the second is used for validation. This is referred to as *fit test-rig data* and *validation test-rig data*. More information about the test-rig can be found at [11]. The *test-rig data* is freely available at [10].

Table 3. Overview of *test-rig data*

Symbol	Description	Unit
Q_{HP}	Heat produced by HP	[W]
P_{HP}	Electric power consumed by HP	[W]
q	Mass flow	[kg/s]
T_R	Return temperature to the HP	[°C]
T_F	Forward temperature from HP	[°C]

2.3 Static Regression Model for estimation of power input to the heat pump

In this section, the method for obtaining the regression model for the estimated consumed electric power $\hat{P}_{HP}$ of the heat pump is described. The method consists of three main steps, a) use the *standard test data* to initially fit coefficients, b) replace the flow q with an estimate based on the valve input vector v , and c) update the coefficients online using *Recursive Least Squares*.

2.3.1 Initial fit using standard test data

To obtain an estimate for the heat pumps consumed electric power $\hat{P}_{HP}$, we formulate a multivariate quadratic polynomial

$$P_{HP} = c_0 + c_1 T_F + c_2 T_R + c_3 q + c_4 T_F^2 + c_5 T_R^2 + c_6 q^2 \quad (1)$$

Which takes the forward temperature T_F , return temperature T_R and mass flow q as inputs. Using the data described in Section 2.2.1 a system of linear equations are formulated in matrix form seen in (2).

$$\mathbf{P}_{HP} = \mathbf{A} \mathbf{c} \quad (2)$$

with $\mathbf{a}_i = [T_{F,i} \ T_{R,i} \ q_i \ T_{F,i}^2 \ T_{R,i}^2 \ q_i^2]$ being the i^{th} row in $\mathbf{A}$ and $\mathbf{c} = [c_0 \ \dots \ c_6]^T$ being the coefficients of (1) to solve for. This system of linear equations are overdetermined, so no exact solution exists. Instead, the coefficients in $\mathbf{c}$ are found by solving the *Least Squares* problem

$$\min_{\mathbf{c} \in \mathbb{R}^6} \|\hat{\mathbf{P}}_{HP} - \mathbf{P}_{HP}\|_2 \quad (3)$$

having solution

$$\mathbf{c} = \mathbf{A}^+ \mathbf{P}_{HP} = (\mathbf{A}^T \mathbf{A})^{-1} \mathbf{A}^T \mathbf{P}_{HP} \quad (4)$$

with $\mathbf{A}^+$ being the pseudo inverse of $\mathbf{A}$. The choice of variables is guided by two objectives. The first being physical relevance and the second is all but one are considered easy to measure. In this case we assume T_F , T_R and P_{HP} to be directly measured during operation leaving only the flow q unmeasured.

2.3.2 Fitting valve input to estimated flow

Since the flow is not measured it is replaced by an estimate based on the set of valve control signals defined as $v \in \{0,1\}^M$ where M is the number of floor heating circuits. To obtain the estimate for the flow, q is isolated in Eq. (1) as seen in Eq. (5).

$$\begin{aligned} \hat{q}_+ &= f_+(T_F, T_R, P_{HP}) \\ &= \frac{-b_{so} + \sqrt{b_{so}^2 - 4a_{so}c_{so}}}{2a} \\ \hat{q}_- &= f_-(T_F, T_R, P_{HP}) \\ &= \frac{-b_{so} - \sqrt{b_{so}^2 - 4a_{so}c_{so}}}{2a} \end{aligned} \quad (5)$$

$$\begin{aligned} c_{so} &= c_0 - P_{HP} + c_1 T_F + c_2 T_R + c_4 T_F^2 + c_5 T_R^2 \\ b_{so} &= c_3 \\ a_{so} &= c_6 \end{aligned}$$

Solving the second order equation in Eq. (1) provides two solutions, so a choice has to be made whether to choose $\hat{q}_+$ or $\hat{q}_-$ for the estimate. The main criteria is that the values of $\hat{q}$ are positive, since a negative flow does not make physical sense in this context. If $c_3, c_6 > 0$, then the choice is always $\hat{q}_+$. This can be obtained by formulating Eq. (3) as a constrained optimization problem, with $c_3, c_6 \geq 0$. This is a linear programming problem, which most solvers can handle.

Since the flow largely is decided by the combination of open valves, a linear regression expression, seen in Eq. (6), is used.

$$\hat{q}_v = f_v(v) = k_1 v_1 + \dots + k_M v_M = \mathbf{k}^T \mathbf{v} \quad (6)$$

This means that $\hat{q}_v$ can be interpreted as a sum of nominal estimates with $\hat{q}_{v,i} = k_i v_i$ being an estimate for the flow q_i . Again the coefficients in $\mathbf{k} = [k_1 \ \dots \ k_M]^T$ are found by minimizing the squared error between $\hat{q}_v$ and $\hat{q}$ using Eq. (3). The data needed to fit the coefficients in $\mathbf{k}$, is measured during operation. The expression for $\hat{q}_v$ in (6) is then inserted into Eq. (1) giving

$$\begin{aligned} \hat{P}_{HP} &= f_{HP}(T_F, T_R, \mathbf{v}) \\ &= c_0 + c_1 T_F + c_2 T_R \\ &\quad + c_3 (\mathbf{k}^T \mathbf{v}) + c_4 T_F^2 + c_5 T_R^2 \\ &\quad + c_6 (\mathbf{k}^T \mathbf{v})^2 \end{aligned} \quad (7)$$

The function f_{HP} is now only a function of measured variables and inputs. Structural-wise the expression is in principle ready for use in a predictive control scheme applied to the system described in Section 2.1.

2.3.3 Recursive least squares update of linear coefficients

Since P_{HP} is measured during operation, it is possible to update the linear coefficients in $\mathbf{c}$, from Eq. (4), recursively as new data comes in. The algorithm applied here is a common *Recursive Least Squares* (RLS), which can be found in standard literature, for further reading [12] and [13]. The RLS algorithm is shown in (8)-(13). To initiate the RLS algorithm a set of initial coefficients $\hat{\mathbf{a}}_0$ and the constant δ must be chosen. As seen in (9), the coefficients from $\mathbf{c}$ is used. The constant

δ is a tweaking parameter, which if chosen low (10^{-5}) only changes the coefficients of $\hat{\mathbf{a}}^{(k)}$ slightly, and if chosen larger the coefficients might wander far from the initial values. In case all circuits are closed, the heat pump is turned off and the step of updating the coefficients is skipped.

$$\mathbf{P}_0 = \delta \mathbf{I}, \mathbf{P}^{(k)} \in \mathbb{R}^{M \times M} \quad (8)$$

$$\hat{\mathbf{a}}_0 = [c_0 \dots c_7]^T \quad (9)$$

CASE (Heat pump is ON)

$$\hat{\mathbf{a}}^{(k)} = \hat{\mathbf{a}}^{(k-1)} + \mathbf{g}^{(k)} \left(\mathbf{y}^{(k)} - \mathbf{x}^{(k)T} \hat{\mathbf{a}}^{(k-1)} \right) \quad (10)$$

$$\mathbf{g}^{(k)} = \frac{\mathbf{P}^{(k-1)} \mathbf{x}^{(k)}}{1 + \mathbf{x}^{(k)T} \mathbf{P}^{(k-1)} \mathbf{x}^{(k)}} \quad (11)$$

$$\mathbf{P}_k = \mathbf{P}_{k-1} - \mathbf{g}_k \mathbf{x}_k^T \mathbf{P}_{k-1} \quad (12)$$

CASE (Heat pump is OFF)

$$\hat{\mathbf{a}}^{(k)} = \hat{\mathbf{a}}^{(k-1)}, \mathbf{g}^{(k)} = \mathbf{g}^{(k-1)}, \mathbf{P}^{(k)} = \mathbf{P}^{(k-1)} \quad (13)$$

2.4 Validation

In this section, we present the MPC control problem, which has been implemented and simulated to prove that the derived expression can take part in a solvable *Mixed-Integer Non-linear Programming* (MINLP) optimization problem.

$$\min_u \left(\mathbf{c}_{HP}^T \mathbf{P}_{HP} + \sum_{i=1}^M c_{s,i} \|\mathbf{T}_{s,i} - \mathbf{T}_{r,i}\|_2^2 \right) T \quad (14)$$

subject to

$$i \in \{1, \dots, M\}, k \in \{0 \dots h_p - 1\} \quad (15)$$

$$\mathbf{c}_{HP} \in \mathbb{R}^{h_p}, c_{s,i} \in \mathbb{R}^+ \quad (16)$$

$$\hat{\mathbf{x}}_i^{(k+1)} = F_x(\mathbf{x}_i^{(k)}, \mathbf{u}_i^{(k)}, \mathbf{d}^{(k)}) \quad (17)$$

$$\hat{\mathbf{x}}_i^{(0)} = \mathbf{x}_0 \quad (18)$$

$$v_i^{(k)} \in \{0, 1\}, \underline{T}_F \leq T_F^{(k)} \leq \overline{T}_F \quad (19)$$

$$f_x(\mathbf{x}_i^{(k)}, \mathbf{u}_i^{(k)}, \mathbf{d}^{(k)}) = \mathbf{A}_i \mathbf{x}_i^{(k)} + \mathbf{B}_{x,i} T_w^{(k)} v_i^{(k)} + \mathbf{B}_{u,i} T_F v_i^{(k)} + \mathbf{D}_i T_a^{(k)} \quad (20)$$

$$\hat{P}_{HP}^{(k)} = f_{HP}(\mathbf{u}^{(k)}, T_R^{(k)}) \quad (21)$$

$$0 \leq \hat{P}_{HP}^{(k)} \leq \overline{P}_{HP} \quad (22)$$

$$\hat{T}_R^k = H(\mathbf{x}^{(k)}, \mathbf{u}^{(k)}) \quad (23)$$

$$H(\mathbf{x}^{(k)}, \mathbf{u}^{(k)}) = \frac{\sum_{i=1}^M k_{u,i} v_i^{(k)} (2T_{w,i}^{(k)} - T_F^{(k)})}{\mathbf{k}_u^T \mathbf{u}^{(k)} + \varepsilon} \quad (24)$$

with vectors and matrices being

$$\mathbf{u}_i^k = [v_i \quad T_F]^T, \quad \mathbf{d}^{(k)} = T_a^{(k)} \quad (25)$$

$$\mathbf{x}_i^k = [T_{r,i}^{(k)} \quad T_{f,i}^{(k)} \quad T_{w,i}^{(k)}]^T \quad (26)$$

$$\mathbf{P}_{HP} = [\hat{P}_{HP}^{(k)} \dots \hat{P}_{HP}^{(h_p)}]^T \quad (27)$$

$$\mathbf{u}^k = [v_1 \dots v_M \quad T_F]^T \quad (28)$$

$$\mathbf{x}^k = [(\mathbf{x}_1^{(k)})^T \dots (\mathbf{x}_M^{(k)})^T]^T \quad (29)$$

$$\mathbf{A}_i = \begin{bmatrix} -\alpha_{a,i} - \alpha_{f,i} & \alpha_{f,i} & 0 \\ \alpha_{f,i} & -\alpha_f - \alpha_w & \alpha_{w,i} \\ 0 & \alpha_{w,i} & -\alpha_{w,i} \end{bmatrix} \quad (30)$$

$$\mathbf{B}_{x,i} = \begin{bmatrix} 0 \\ 0 \\ -\frac{2\bar{q}c_w}{c_w} \end{bmatrix}, \mathbf{B}_{u,i} = \begin{bmatrix} 0 \\ 0 \\ \frac{2\bar{q}c_w}{c_w} \end{bmatrix} \quad (31)$$

$$\mathbf{D}_i = \begin{bmatrix} u_{a,i} \\ 0 \\ 0 \end{bmatrix} \quad (32)$$

Superscript indicates the time period with $k \in \{0, \dots, h_p\}$ being the prediction window. In this example, the control and prediction horizon have the same length. The room number is indicated in subscript using i , with M being the number of rooms.

The cost function is quadratic and punishes energy consumption by the heat pump and divergence from the reference temperature. The vectors $\mathbf{T}_{s,i}$ and $\mathbf{T}_{r,i}$ contain the room temperature reference and estimated room temperatures for room i over the prediction window, respectively. The vector $\mathbf{c}_{HP}$ contains the cost weights for each sample and have the unit euro per watt-hour [€/Wh]. The discomfort penalty for room i is $c_{s,i}$ with unit euro per kelvin squared hour [€/K²h]. The sample time ΔT has unit hours [h]. The cost on temperature deviation is quadratic to punish both under and overheating of a room.

The function $F_x(\mathbf{x}_i, \mathbf{u}_i, \mathbf{d})$ is a 4th order Runge-Kutta [14] integration of the dynamics $\dot{\mathbf{x}}_i = \mathbf{f}_x(\mathbf{x}_i, \mathbf{u}_i, \mathbf{d})$. The dynamics are implemented using multiple shooting [15].

The control signals in $\mathbf{u}$ are constrained according to (20), with the valve control signals being binary.

The model, seen in (21), reflects an RC-equivalent model, with two bilinear terms. The bi-linearity arises from the fact that both forward temperature and valve states are control inputs. The parameters α represent heat conductance [W/K], c_w is heat capacity [J/K] and c_w is specific heat capacity for water.

The estimated power consumption of the heat pump is $\hat{P}_{HP}^k$, which is derived in Sec. 2.3.

The return temperature T_R^k is calculated using the output function $H(\mathbf{x}^k, \mathbf{u}^k)$. The output function is derived based on the energy balance in a mixing circuit seen in Eq. (33).

$$c_w q T_R = c_w q_1 T_{R,1} + \dots + c_w q_M T_{R,M} \Leftrightarrow \quad (33)$$

$$T_R = \frac{q_1 T_{R,1} + \dots + q_M T_{R,M}}{q} \quad (34)$$

Since we do not have a measure of q or q_i we replace it with the estimate $\hat{q}_v$ seen in (6) and the nominal estimates for each circuit $\hat{q}_{v,i}$. For Eq. (34) to make sense $\hat{q}_{v,i}$ has to be non-zero and positive.

$$T_R = \frac{k_1 v_1 T_{R,1} + \dots + k_M v_M T_{R,M}}{\mathbf{k}^T \mathbf{v}} \quad (35)$$

Further, the room model $f_x(\mathbf{x}_i^k, \mathbf{u}_i^k, \mathbf{d}^k)$ is fitted assuming the water temperature of room i , $T_{w,i}$, is the average of forward temperature T_F and return temperature, $T_{R,i}$, as seen in Eq. (36).

$$T_{w,i} = \frac{T_{R,i} + T_F}{2} \quad (36)$$

Isolating $T_{R,i}$ gives

$$T_{R,i} = 2T_{w,i} - T_F \quad (37)$$

which gives the result

$$\hat{T}_R = \sum_{i=1}^M \frac{k_i^T v_i (2T_{w,i} - T_F)}{\mathbf{k}^T \mathbf{v} + \epsilon} \quad (38)$$

A small constant ϵ is added to avoid division by zero.

3 Results

3.1 Regression results

The overall result regarding the regression is that the initial regression fit performs acceptable without further update of the parameters. This said, we show that an improvement is obtained by updating the coefficients recursively.

3.1.1 Regression from standard test data

The result of for the initial regression expression fitted to the *standard test data* is presented in Figure 2.

Figure 2. (Left) shows the regression result compared with original data used for the fit, (Right) shows the result compared with the *validation data* from test-rig.

As seen in the left sub-figure the r^2 value is close to one, indicating that no more information can be extracted from the 18 samples. The picture changes when the model is compared to the *validation data* where the inaccuracies get clearer with $r^2 \approx 70\%$.

The fitted expression with numerical values is

$$\begin{aligned} \hat{P}_{HP} = & 2128.381 - 98.954T_F - 60.415T_R \\ & + 916.960q + 2.809T_F^2 \\ & + 0.0992T_R^2 + 7533.07q^2 \end{aligned} \quad (39)$$

Table 4. Root mean square error (RMSE) using different combinations of data and regression model. The model used is indicated with equation reference.

Data	Eq. (1)	Eq. (7)
Standard test data	$RMSE = 26$	
Test-rig validation/fit data	$RSME = 472$	$RMSE = 506$

Notice that mass flow q and forward temperature T_F increase the cost and return temperature T_R decreases it. This makes good sense, since a high return temperature means that less energy has to be induced to reach the requested forward temperature.

3.1.2 Results for linear regression of the flow

This section contains the results for the linear regression model of the flow seen in Eq. (6) and the isolated flow estimate $\hat{q}_+$ seen in (5). To obtain a series of data points for $\hat{q}_+$ measurements of T_F , T_R and P_{HP} from the first 10 days of the *test-rig data* is used.

Figure 3. Shows the estimated flow obtained by isolating the flow q in the regression model obtained from the standard test data and thereafter fitting a new regression model based on the valve input.

As can be seen in Figure 3 the estimate $\hat{q}_+$ is catching the trend, but it does overestimate at large values when compared to the flow measurements obtained from the test-rig. Interesting enough, the results improve when the linear regression model for $\hat{q}_v$, based on the control valve input signals, is used. This indicates that the initial assumption that the flow is a sum of nominal flows from each circuit is correct. Since $\hat{q}_+$ is calculated by solving a second order equation complex roots can appear. This was experienced in this particular investigation. The complex roots were few and handled by using the real part only.

3.1.3 Results for recursive least squares update of the coefficients

The results from the RLS update of the coefficients in the regression model (7) show that it is possible to improve the estimate of the power input by use of online measurements. The graphs in Figure 4 compare the performance between RLC, for the cases $\delta = 10^{-5}$ and $\delta = 10^6$, and the original fit from (7).

Figure 4. (left) Shows how the root mean squared error (RMSE) of the estimate of P_{HP} compared with the *validation data* set progresses for all iterations. (right) shows the last iterations, after the initial settling period.

The RMSE reduces from the original value of 506[W], obtained using the regression model from (7), to approx. 400[W] for $\delta = 10^{-5}$ and 360[W] for $\delta = 10^6$ when compared to the *validation data*. To provide an overview on how such an improvement looks the time series results are presented in Figure 5.

The results showed a high value ($\delta = 10^6$) caused a significant improvement to the estimation as seen on the absolute cumulative error in Figure 5. The total energy consumption of the heat pump over the validation period, seen in Figure 5, is approx. 70 kWh, which gives the following relative accuracy errors seen in Table 5 with relative accuracy error e_r defined in Eq. (40).

$$e_r = \frac{|\hat{x} - x|}{x} \quad (40)$$

Where $\hat{x}$ is the estimate and x the measured value.

Table 5. Relative accuracy error for the consumption est.

Fit from Eq. (7)	RLS (10^6)	RLS (10^{-5})
21.2 %	16.9 %	20.5%

The cost of choosing δ large is a very poor estimate in the initial period, seen in Figure 4.

Figure 5. The upper row shows the contribution from each of the measurements swept over their operating area. The fan of lines represent their value as the RLS algorithm progresses. The red line is the final result. The lower line of figures shows the actual value of the coefficients as they progress for each iteration.

It took 2 days before the estimates improved compared to the initial fit. Further, the values of the

coefficients were highly volatile before converging as seen in Figure 6. In contrast with $\delta = 10^{-5}$ the coefficients were more steady, but the improvement in estimate was insignificant when compared to the *validation data*.

The curves in the upper row of Figure 6 and Figure 7 show the individual contribution from each measurement to the full expression. The curves are generated by setting every measurement except one to zero, then making a sweep over the remaining. One curve is made for each set of coefficients as they develop over time. The lighter lines are early solutions while the darker are later solutions. The red line is the final, curve. This is done to give an idea of how the components of the function develops as the RLS algorithm progresses.

Figure 7. Shows change in coefficients for $\delta = 10^{-5}$.

The main conclusion is that both choices of δ have advantages and disadvantages. If faster settling time and low coefficient volatility is priority then δ should be chosen low. If the accuracy of the estimate is of highest priority, then a high value could be chosen.

3.2 Results for MPC validation example

The results from the simulation of the model predictive control (MPC) algorithm containing the heat pump model, described in Section 2.4, is presented here. Since the focus is on solvability, several simplifications have been made. First, the model used for simulation is the same as the model described in the optimization

Figure 6. Comparison between measured data, initial fit and recursive fit evaluated on the validation data.

problem leaving out any model uncertainties. Additionally, it is assumed that future values, such as ambient temperature are known, fundamentally making it deterministic MPC. This said the optimization problem is solvable on a standard laptop (Lenovo T490s) as seen in Figure 8, which shows the progress of the states over the simulation window for each of the four rooms. The optimization problem is implemented in MATLAB using CasADi [16] for formulation and BONMIN as solver. The constraints in the optimization problem are relaxed using slack variables, when necessary, to maintain feasibility during simulation. The code is available in the public repository [10].

This particular example presented in Figure 8 and Figure 9 is solved using a sample time of 15 minutes and a prediction horizon of 8 samples corresponding to a length of 2 hours. This is relatively short, considering the time constants of a building. The deciding factor for the length of the prediction horizon is the complexity of the problem. The complexity of a *Mixed-Integer Programming problem* increases very fast with the length of the window. In this case, a prediction horizon of 10 samples occasionally took 30 min. to solve, which is problematic when the sample time is 15 min. Further, this issue only increases when more rooms are added to the problem, calling for another approach. A work-around is to use continuous variables in the range $[0,1]$ and round to the closest integer. In this case solving time is seconds for windows of approx. 6 hours.

Simulation results for the MPC algorithm

Figure 8. Shows the states and the valve control signals as they develop throughout the simulation. The states are room temperature T_r , floor temperature T_f and an averaged water temperature in the pipe T_w . The input is the binary opening degree of the control valves.

The main conclusion from Figure 8 is that the controller is able to bring the room temperature to the reference using the discrete control inputs, which proves that the heat pump model can take part in a larger control problem.

Figure 9 presents the results, which are directly related to the regression model of the heat pump. The three plots in Figure 9 show the estimate for the consumption $\hat{P}_{HP}$ and the three inputs forward

temperature T_F , return temperature T_R and combined flow q in the floor heating circuit. Using common sense, the following situations led to high power consumptions. A large flow, means a larger mass needs to be heated, a large difference between return and forward temperature also naturally demands more energy. Further, a high forward temperature lowers the *Carnot Coefficient of Performance* (COP_{Carnot}) due to the increased difference between cold (brine temperature) and warm (forward temperature) reservoir.

Figure 9. (Upper) Shows the input forward temperature T_F and the estimated return temperature T_R . (Middle) Shows the estimated power consumption of the heat pump. (Lower) shows the estimated flow to and from the heat pump.

Some of these patterns are visible in the results. In the first six hours the difference $T_F - T_R$ is large combined with a high forward temperature which result in a high energy consumption, even though the flow is low. In the hours between 7 and 13, the consumption is lower, mainly due to the small difference between forward and return temperature. In the last period from hour 13 and onwards, the power consumption increases again due the combination of flow combined with rising forward temperature. It is an important conclusion that the power consumption increases with the forward temperature, since this effect reflects the drop in COP_{Carnot} . Note that the return temperature is estimated, and the expression seen in (38) is directly dependent on forward temperature. This might cause the value to be volatile, and highly affect the estimate for the power consumption, therefor and improvement in this estimate should lead to better estimates for the power consumption.

4 Conclusion

In this paper, a quadratic regression model estimating the power consumption of a heat pump connected to ON/OFF controlled floor heating is presented. The data and measurements, used for fitting the coefficients, are chosen based on degree of availability in such an installation.

The data is extracted from a report containing common manufacture-commissioned tests intended to measure the COP under controlled conditions. The validation and recursive update is performed using the data obtained from the test-rig. Both data sets are made available for the purpose of scrutiny and further work.

The regression model is integrated into a *Mixed-Integer Non-linear* MPC problem which is proven solvable by example. In the spirit of this text, one has to emphasise that the MPC only could be solved with a window length up till 2 hours, on a standard laptop, and calculation time for an iteration could take as long as 30 minutes. This is troubling, since the model consists of only four rooms and with the type of time constants in play a window length of minimum 6 hours is much more beneficial.

The results indicate that there is enough information contained in the few data points from the *standard test data* to establish a cost relation between control inputs to the heat pump and the power consumption. This relation is important since an actual price can be attached to the power consumption enabling the use of *Economic MPC (EMPC)*.

Since the data from the standard test seems to hold value in other contexts than for calculating COP and SCOP, the authors propose these test become mandatory and publicly available. One could imagine an online database containing operational data for all commercial models.

Because both the *Recursive Least Squares* (RLS) method and MPC are repetitive algorithms, it does not take much imagination to consider running the recursive algorithm parallel with the MPC algorithm. This approach might cause the optimization problem to become infeasible, due unexpected changes in the estimate of the heat pump power. Since this claim stays untested, we will not comment on it further.

The next logical step is to test the method against a heat pump, which is installed in a real house. Further, it is interesting to investigate whether a similar expression, using outside temperature, can be obtained for an air-to-water heat pump. At last, an investigation of a more meaningful formulation of a model predictive controller, using the heat pump model is in its place.

References

- [1] European Heat Pump Association, “ehpa - hp sales,” european heat pump association, 1 January 2017. [Online]. Available: http://stats.ehpa.org/hp_sales/story_sales/. [Accessed 8 Januar 2021].
- [2] S. Rastegarpour, S. Gros and L. Ferrarini, “MPC approaches for modulating air-to-water heat pumps in radiant-floor buildings,” *Control Engineering Practice*, vol. vol. 95, p. p. 104209, 2020.
- [3] H. Weeratunge, G. Narsilio, J. d. Hoog, S. Dunstall and S. Halgamuge, “Model predictive control for a solar assisted ground source heat pump system,” *Energy*, vol. vol. 152, p. pp. 974–984, 2018.
- [4] DIN Deutsches Institut für Normung e. V., “Beuth, DIN EN 14511-2:2019-07,” Beauth, 7 January 2021. [Online]. Available: <https://www.beuth.de/en/standard/din-en-14511-2/298537580>. [Accessed 7 January 2021].
- [5] DIN Deutsches Institut für Normung e. V., “Beuth, DIN EN 14825:2019-07,” Beuth Publishing DIN, 7 January 2021. [Online]. Available: <https://www.beuth.de/de/norm/din-en-16147/254893177>. [Accessed 7 January 2021].
- [6] DIN Deutsches Institut für Normung e. V., “Beuth, DIN EN 16147:2017-08,” Beuth Publishing DIN, 7 January 2021. [Online]. Available: <https://www.beuth.de/en/standard/din-en-16147/254893177>. [Accessed 7 January 2021].
- [7] F. Simon, J. Ordoñez, T. Reddy, A. Girard and T. Muneer, “Developing multiple regression models from the manufacturer’s ground-source heat pump catalogue data,” *Renewable Energy*, vol. 95, pp. 413-421, 2016.
- [8] X. Xu, J. Liu, Y. Wang, J. Xu and J. Bao, “Performance evaluation of ground source heat pump using linear and nonlinear regressions and artificial neural networks,” *Applied Thermal Engineering*, vol. 180, p. 115914, 2020.
- [9] S. Thorsteinsson, *Heat pump connected to floor heating*, Aalborg: zenodo, 2021. DOI: 10.5281/zenodo.4445311
- [10] S. Thorsteinsson, “gitlab,” gitlab, 16 January 2021. [Online]. Available: <https://gitlab.com/Thorsteinsson/cold-climate-hvac-2021.git>. [Accessed 16 January 2021].
- [11] R. C. S. Ø. Jensen, T. Green, K. Vinther, T. Minko, J. Bendtsen, J. Pålsson, K. Prølls, L. Li and P. Dermont, “teknologisk.dk,” Dansk Teknologisk Institut, September 2017. [Online]. Available: <https://www.teknologisk.dk/optimering-af-gulvvarme-og-varmepumpesystemer/39663>. [Accessed 12 January 2017].
- [12] P. C. Young, *Recursive Estimation and Time-Series Analysis*, 2nd ed., Berlin Heidelberg: Springer-Verlag Berlin Heidelberg 2011, 2011, pp. 30-34.
- [13] R. Qi, G. Tao and B. Jiang, *Fuzzy System Identification and Adaptive Control*, Cham: Springer Nature Switzerland AG, 2019.
- [14] J. C. Butcher, *Numerical Methods for Ordinary Differential Equations*, West Sussex: Wiley, 2016.
- [15] C. Kirches, *Fast Numerical Methods for Mixed-Integer Nonlinear Model-Predictive Control*, Heidelberg: Springer, 2010.
- [16] J. A. E. Andersson, J. Gillis, G. Horn, J. B. Rawlings and M. Diehl, “CasADi - A software framework for nonlinear optimization and optimal control,” *Mathematical Programming Computation*, vol. 11, pp. 1-36, 2019.