Distributionally Robust Stochastic Optimal Power Flow Considering N-1 Security Constraints with renewable

Shiyuan Ni¹, Guilian Wu¹, Zehao Wang², Yi Lin¹, Defei Yao² and Ruosi Zhang^{2,*}

¹ State Grid Fujian Electric Power Co., Ltd, Economic and Technological Research Institute, 35003 Fuzhou, China

²Tsinghua University, Sichuan Energy Internet Research Institute, 610213 Chengdu, China

Abstract. This paper proposes a data-driven stochastic optimal power flow model considering the uncertainties of renewable energy sources. The proposed model also focuses on the constraints of reactive voltage, aiming at improving the safety of voltage amplitude and reactive power output at each bus. Using data-driven linearization techniques, we simplified the calculation of system. In addition, Wasserstein ambiguity set was used to describe the uncertainties of renewable energy prediction error distribution, and a robust stochastic optimal power flow model considering N-1 security constraints is established. The simulation results on IEEE-39 system showed the accuracy and effectiveness of the distributionally robust optimization model and the reactive voltage constraint model provided a more stable operation schedule.

1 Introduction

The grid-connected operation of Renewable Energy Sources (RESs) makes the balance between the economic benefits of the transmission grid and the reliability or safety of the system more complicated. In recent researches, stochastic optimization (SO) and robust optimization (RO) are currently used to tackling optimal power flow (OPF) with uncertainties. However, the SO assumed that prediction errors of uncertainties followed a certain probability distribution, such as Gaussian distribution[1]. These assumptions are unreasonable and cannot simulate the real power system operating characteristics due to the complex nonlinear phenomena. What's more, the RO completely ignores the statistical information of uncertainties, leading to conservative solutions. In the real world, the probability distribution of prediction errors can only be calculated from limited data sets, so data-driven methods[2] have been widely used in stochastic OPF models with Conditional Value-at-Risk (CVaR) [3]. Distributionally Robust Optimization (DRO) method [4] combined the above-mentioned stochastic OPF with the traditional RO, using historical data to estimate the parameters of the distribution[5]. It minimized the operation cost of the system under the worst case of uncertainties distribution and considered both robustness and conservativeness.

However, the existing power transmission grid model with uncertainties does not take into account the constraints of the node voltage and the reactive power output of the generators, which will cause the calculation to be inconsistent with the real world. This paper establishes a multi-period data-based DRO model for the transmission grid OPF with renewable energy and storage, which also fully takes into account the voltage

magnitude constraints and reactive power constraints of each node in the system for optimization. The results on the IEEE-39 case showed that safer and more economical strategies for the system can be made base on our DRO model considering voltage and reactive power.

2 Stochastic OPF model

Let $V_i^t = V_i^t \angle \theta_i^t \in \mathbb{C}$ denotes the voltage at node $i \in N$ at time t , which $N = \{1, 2, \dots, N\}$ is a set of buses, and $t \in T$ is the operating horizon. V_i^t is the voltage magnitude and θ_i^t is the phase angle. Define the complex vectors $\mathbf{v}^t := [V_1^t, V_2^t, \dots, V_N^t]^T \in \mathbb{C}^N$. Let z_{ij} be the complex impedance of the line between bus i and bus j , then the line admittance is $y_{ij} = 1/z_{ij} = g_{ij} + jb_{ij}$. The admittance matrix is $\mathbf{Y} \in \mathbb{C}^{N \times N}$. The power bus injections are given by

$$P_i^t = \sum_{j=1}^N g_{ij} V_i^t V_j^t \cos \theta_{ij}^t + \sum_{j=1}^N b_{ij} V_i^t V_j^t \sin \theta_{ij}^t, i \in N, t \in T \quad (1)$$

$$Q_i^t = -\sum_{j=1}^N b_{ij} V_i^t V_j^t \cos \theta_{ij}^t + \sum_{j=1}^N g_{ij} V_i^t V_j^t \sin \theta_{ij}^t, i \in N, t \in T \quad (2)$$

Where P_i^t and Q_i^t indicate active and reactive power injection at bus i . $\theta_{ij}^t = \theta_i^t - \theta_j^t$ are the difference of phase angles between bus i and bus j . Vectors of active and reactive power are $\mathbf{p}^t = [P_1^t, P_2^t, \dots, P_N^t]^T$ $\mathbf{q}^t = [Q_1^t, Q_2^t, \dots, Q_N^t]^T$. The line transmission power between bus i and bus j are given

* Corresponding author: zrs120100@sina.com

$$P_l^{m,t} = \left((V_i^t)^2 - V_i^t V_j^t \cos \theta_{ij}^t \right) g_{ij} - V_i^t V_j^t \sin \theta_{ij}^t b_{ij}, m \in E \quad (3)$$

$$Q_l^{m,t} = - \left((V_i^t)^2 - V_i^t V_j^t \cos \theta_{ij}^t \right) b_{ij} - V_i^t V_j^t \sin \theta_{ij}^t g_{ij}, m \in E \quad (4)$$

where $P_l^{m,t}$ and $Q_l^{m,t}$ indicate active and reactive line transmission power, and $\mathbf{p}_l^t = [P_l^{1,t}, P_l^{2,t}, \dots, P_l^{L,t}]^T$, $\mathbf{q}_l^t = [Q_l^{1,t}, Q_l^{2,t}, \dots, Q_l^{L,t}]^T$ are the vectors of them at time t .

In addition, OPF model has various constraints on grid-connected devices and branches including generator ramping limits, state of charge limitations for energy storage devices, power injection ranges, voltage magnitudes and line flows and other device limits. All these constraints can be modeled or approximated as linear inequalities form as

$$\mathbf{T}\mathbf{x} \leq \omega \quad (5)$$

where $\mathbf{x} = [\mathbf{p}_g^T, \mathbf{q}_g^T, \mathbf{p}_e^T, \mathbf{q}_e^T, \mathbf{p}_l^T, \mathbf{q}_l^T, \mathbf{v}^T, \mathbf{p}_{es}^T, \mathbf{q}_{es}^T, \mathbf{e}_{es}^T]^T$, $\mathbf{p}_g^T, \mathbf{q}_g^T, \mathbf{p}_e^T, \mathbf{q}_e^T$ are active and reactive power of generators and energy storages respectively, $\mathbf{e}_{es}^T$ is the state of charge for energy storage.

Power balance is given as

$$\begin{aligned} \mathbf{p} &= \mathbf{p}_g - \mathbf{p}_l \\ \mathbf{q} &= \mathbf{q}_g - \mathbf{q}_l \end{aligned} \quad (6)$$

where $\mathbf{p}_l, \mathbf{q}_l$ is the active and reactive power for loads at bus i .

To deal with the non-convex of AC power flow, this paper adopts a data-driven linearization method [6]. The data-driven linearization method is based on formulas(1) and (2) to obtain the linearized power flow equation by using the inverse regression model, that is, the unknown variable V_i, θ_i is the function of the known variable P_i, Q_i .

Arrange the formula based on different types of buses in the following sequence $PQ, PV, V\theta$ with subscript L, S, R respectively. The inverse regression equations can be expressed as a block matrix form as

$$\mathbf{V}_{L,S,R} = \mathbf{A}_v \begin{bmatrix} \mathbf{p}_{L,S} \\ \mathbf{q}_{L,S,R} \end{bmatrix} + \mathbf{C}_v \quad (7)$$

where $\mathbf{A}_v$ and $\mathbf{C}_v$ are the coefficient matrix related to voltage calculation. The branch power flow (3) can be mapped by regression from P_l^m, Q_l^m to P_i similar to the mapping of power injection:

$$\mathbf{p}_l = \mathbf{\Gamma}_{PF} \begin{bmatrix} \mathbf{p} \\ \mathbf{q} \end{bmatrix} + \mathbf{C}_{PF} \quad (8)$$

where $\mathbf{\Gamma}_{PF}$ is the coefficient matrix related to branch power flow calculation.

Based on data-driven power flow linearization model, the stochastic OPF model considering voltage constraints given as:

$$\min \sum_{t=0}^T E(h_t) \quad (9)$$

$$\text{s.t. } \text{ER} \{(\mathbf{W}\mathbf{x} + \mathbf{K}) - \mathbf{G}\} \leq 0 \quad (10)$$

$$\text{ER} (\mathbf{T}\mathbf{x}_t - \omega) \leq 0 \quad (11)$$

$$\mathbf{C}\mathbf{x}_t + \mathbf{L} = \mathbf{0} \quad (12)$$

where $\mathbf{x}$ includes all the decision variables, $\mathbf{R}$ indicates the transformation of the inequality constraints into stochastic versions, h denotes the operating cost of the grid, $E(\cdot)$ is the expectation of variables. Constraints (10) includes the stochastic form of voltage magnitude and branch power flow constraints based on linearized equations, constraint (11) is the stochastic form of constraint (5), formula (12) is the matrix form of power balance equations.

Due to the uncertainty of renewable energy, ξ defines vectors of variables' forecast errors, so the affine form

$$\mathbf{x} = \mathbf{F}\xi + \mathbf{D} \quad (13)$$

where $\mathbf{x}$ is parameterized by a nominal value $\mathbf{D}$ plus a linear function $\mathbf{F}$ of prediction error of uncertainties ξ . Define a set V_i includes N_i constraints (10)-(11), each individual constraint in the set can be written in the affine form as

$$\eta_o(F, D, \xi) = [\mu(F)]_o \xi + [\theta(D)]_o, o = 1, \dots, N_i \quad (14)$$

where, $\eta_o(\cdot)$ is the o -th affine constraint in the set V_i .

The CVaR with risk level β in the set V_i is

$$\inf_{\sigma_o} E_{\xi} \left\{ \left[C_o(F, D, \xi) + \sigma_o \right]_+ - \sigma_o \beta \right\} \leq 0 \quad (15)$$

where, $[\cdot]_+$ indicates positive values making sense, $\sigma_o \in R$ is an auxiliary variable[7]. The expectation of (15) is expressed in the form

$$\Delta_o = \max_{k=1,2} \left[\langle \alpha_{ok}(\mathbf{y}), \xi \rangle + \beta_{ok}(\sigma_o) \right] \quad (16)$$

where $\langle a, b \rangle := a^T b$, the decision variable $\mathbf{y} = \{F, D, \sigma\}$.

When $k=1$: $\alpha_{o1}(\mathbf{y}) = [\mathbf{W}\mathbf{F}]_o, [\mathbf{W}\mathbf{D}]_o$;

$\beta_{o1}(\sigma_o) = [-\mathbf{G} + \mathbf{W}\xi + \mathbf{K}]_o + \sigma_o - \sigma_o \beta$. When $k=2$,

$\alpha_{o2}(\mathbf{y}) = [\mathbf{0}]$; $\beta_{o2}(\sigma_o) = -\sigma_o \beta$.

3 Data-driven distributionally robust stochastic optimal power flow

In the optimization model, the distribution P of uncertainties ξ should be well known, but the real distribution cannot be obtained from limited data. An empirical distribution can be obtained from limited historical data, and the "distance" between the real distribution and the empirical distribution can be defined by Wasserstein radius, so the distribution of uncertainties belongs to the ambiguity set

$$\hat{P}^{N_s} := \left\{ P \in \mathcal{M}(\Xi) : d_w(\hat{P}^{N_s}, P) \leq \varepsilon \right\} \quad (17)$$

which contains all the distributions within a Wasserstein ball of radius ε centered at uniform empirical distribution $\hat{P}^{N_s}$. Where is the support set, N_s is the total

number of training dataset, $M(\Xi)$ defines the space contains all probability distributions supported on a set Ξ , d_w is the 1-Wasserstein distance between $\hat{P}^{N_s}$ and P known as Wasserstein metric. The specific information can refer to [8].

The goal of Multi-stage distributionally robust stochastic optimal problem is to minimize the weighted sum of an operating cost and a constraint violation risk under the worst-case distribution in the forecast ambiguity set

$$\min \max E(J_{Cost} + \rho J_{Risk}) \quad (18)$$

where J_{Risk} defines constraint violation risk function, which is a sum of CVaR of a set of constraint functions:

$$J_{Risk} := \sum_{i=1}^{N_\ell} CVaR_P^\beta \quad (19)$$

where $\beta \in (0,1]$ refers to the confidence level of the CVaR under the distribution P of the variable ξ ; ρ is a weight; J_{Cost} is the operating cost function:

$$J_{Cost} = \sum_{d \in G} c_{2,d} (P_G^d)^2 + c_{1,d} P_G^d + c_{0,d} \quad (20)$$

Based on (16), the constraint violation risk function of objective function can be transformed to

$$\hat{J}_{Risk} = \sum_{o=1}^{N_\ell} \sup_{F \in \hat{P}^{N_s}} E^F \max_{k=1,2} \left[\langle \alpha_{ok}(\mathbf{y}), \hat{\xi} \rangle + \beta_{ok} \sigma_o \right] \quad (21)$$

In this paper, we also consider the security constraints of transmission system. The outages included any single generators, lines, or loads, taking total $G_c + G_n + L + N_L$ possible outages. Define $P_{mis}^j \in R$ for the generation-load mismatch given by

$$P_m^j = \begin{cases} P_L^j - P_G^j, & \text{if } j \in \{0\} \cup I_l \\ P_L^j, & \text{if } j \in I_L \\ -P_G^j, & \text{if } j \in I_G \end{cases} \quad (22)$$

where I_G , I_l and I_L are the sets of outages corresponding to a generator, a line and a load. $\{0\}$ means no outage, and $I \equiv \{0\} \cup I_G \cup I_L \cup I_l$. We also define another respond matrix R_m^j , the decision variable becomes

$$\mathbf{x} = \mathbf{D} + \mathbf{F}\xi + \mathbf{R}_m^j \mathbf{P}_m^j \quad \forall j \in I \quad (23)$$

Considering N-1 security constraints of transmission system, the decision variable becomes $\mathbf{y} = \{F, D, R_m\}$, so the data-driven distributionally robust stochastic linearization OPF:

$$\begin{aligned} \min_{\mathbf{y}, \sigma_o} E[\hat{J}_{Cost}] + \rho \max_{F \in \hat{P}^{N_s}} \sum_{o=1}^{N_\ell} E^F [\Delta_o] \\ = \min_{\mathbf{y}, \sigma_o, \gamma_o, K_{io}, \varphi_{iko}} E[\hat{J}_{Cost}] + \sum_{o=1}^{N_\ell} \left(\gamma_o \varepsilon + \frac{1}{N_s} \sum_{i=1}^{N_s} K_{io} \right) \end{aligned} \quad (24)$$

$$\rho \left(\beta_{ok}(\sigma_o) + \langle \alpha_{ok}(\mathbf{y}), \hat{\xi}^i \rangle + \langle \varphi_{iko}, \mathbf{d} - H \hat{\xi}^i \rangle \right) \leq K_{io} \quad (25)$$

$$\|H^T \varphi_{iko} - \rho \alpha_{ok}(\mathbf{y})\|_{\infty} \leq \gamma_o \quad (26)$$

$$\zeta_{iko} \geq 0 \quad (27)$$

$$\frac{1}{N_s} \left[(\mathbf{W}(\mathbf{D} + \mathbf{F}\xi + \mathbf{R}_m^j \mathbf{P}_m^j) + \mathbf{K}) - \mathbf{G} \right] \leq 0 \quad (28)$$

$$\mathbf{C}\mathbf{x} + \mathbf{L} = \mathbf{0}, \forall i \leq N_s, \forall o \leq N_\ell, k = 1, 2 \quad (29)$$

where $\Xi := \{\xi \in R^{N_s} : H\xi \leq \mathbf{d}\}$ is ambiguity set, constraint (27) indicates the ambiguity set non-empty. When $\varphi_{iko} = 0$, there is no uncertainty in the model.

$K_{io} = \rho \left(\langle \alpha_{ok}(\mathbf{y}), \hat{\xi}^i \rangle + \beta_{ok}(\sigma_o) \right)$, γ_o is the auxiliary variable.

4 Case studies

A modified IEEE-39 bus test system shown in Fig. 1 is taken as an example to prove the effectiveness of the proposed model. Two wind farms are connected to bus #30 and bus #34 with the normal power 700MW and 500MW respectively, and the corresponding conventional generators are removed. The energy storage systems are also placed in the system at certain bus and the locations are marked by orange boxes. Their capabilities are $500 \text{ kW} \cdot \text{h}$. To simplify our presentation, only two line flows are handled with distributionally robust optimization with red lines in the figure. The rest of line flows are modeled by N-1 security constraints with CVaR. In addition, conditional risk values of voltage magnitude are added to the objective function.

Fig. 1. Modified IEEE-39 bus test system

The accuracy of data-driven linearization model is related to the size of regression training dataset. We use the size of training data is 1000. Compared with AC power flow, we use the maximum error to demonstrate the accuracy of the model. The error of voltage magnitude is 0.001 p.u., and the error of active line flow is 2.65 MW. Therefore, the results of the linearized model meet the requirements of calculation accuracy.

We assumed the forecast errors have zero mean and standard deviations of 300MW and the operating period was 24H. Wasserstein radius measures the distance between the real distribution and the empirical distribution. The larger the radius is, the greater uncertainties of the real distribution is, and the more conservative the solution is. In Fig. 2 shows the solutions of the proposed data-driven distributionally robust stochastic linearized OPF for varying risk

aversion and Wasserstein radius. When the branch line flows and voltage magnitudes did not exceed the boundary, the CVaR value may be negative. When $\varepsilon = 0$, the model is a deterministic model. It can be concluded that there is a tradeoff between operating cost and CVaR. Larger CVaR corresponds to lower operating cost, and larger Wasserstein radius corresponds to larger operating cost and CVaR. The conservativeness of generator control strategy can be realized by adjusting ρ and ε .

Fig. 2. Tradeoffs between operating cost and CvaR

Furthermore, taking branch #34 as an example, **Fig. 2** shows the line flow varying with ρ and ε . This simulation shows that large ε and ρ ensures smaller line constraint violation. We can make some important constraints weight to higher their priority. Furthermore, this simulation also proves that the conservativeness can be controlled by changing values of ε and ρ . Similar to the analysis of branch power flow, the dotted line indicates the upper and lower bound of voltage magnitude. We treated bus #14 as an example, the variations are shown in **Fig. 4**. When ε and ρ are small, it causes overvoltage at some time point. As ε and ρ increase, all the voltages become lower than their bounds. This leads to better robustness to forecast errors.

Fig. 3. Variations of line flow with different ε and ρ

5 Conclusion

In conclusion, the data-driven power flow linearization model used in this paper has high accuracy and meets the practical production. The value of Wasserstein radius and risk affect the optimal solution of stochastic optimization, and with their increasing values branch line flow and voltage magnitude become lower than their

bounds. Considering the reactive power and voltage constraints in the model, the risk of overvoltage will be significantly reduced to keep the voltage quality at buses and maintain safe and stable operation.

Fig. 4. Variation for voltage magnitude with different ε and ρ

References

1. A. Venzke, L. Halilbasic, U. Markovic, G. Hug, and S. Chatzivasileiadis, "Convex relaxations of chance constrained AC optimal power flow," *IEEE Transactions on Power Systems*, vol. 33, no. 3, pp. 2829–2841, (2017).
2. M. Vrakopoulou, K. Margellos, J. Lygeros, and G. Andersson, "A Probabilistic Framework for Reserve Scheduling and N-1 Security Assessment of Systems With High Wind Power Penetration," *IEEE Transactions on Power Systems*, vol. 28, no. 4, pp. 3885–3896, (2013).
3. T. Summers, J. Warrington, M. Morari, and J. Lygeros, "Stochastic optimal power flow based on conditional value at risk and distributional robustness," *International Journal of Electrical Power & Energy Systems*, vol. 72, pp. 116–125, (2015).
4. W. Xie and S. Ahmed, "Distributionally robust chance constrained optimal power flow with renewables: A conic reformulation," *IEEE Transactions on Power Systems*, vol. 33, no. 2, pp. 1860–1867, (2017).
5. R. A. Jabr, S. Karaki, and J. A. Korbane, "Robust multi-period OPF with storage and renewables," *IEEE Transactions on Power Systems*, vol. 30, no. 5, pp. 2790–2799, (2014).
6. Y. Liu, N. Zhang, Y. Wang, J. Yang, and C. Kang, "Data-driven power flow linearization: A regression approach," *IEEE Transactions on Smart Grid*, vol. 10, no. 3, pp. 2569–2580, (2018).
7. R. T. Rockafellar, S. Uryasev, and others, "Optimization of conditional value-at-risk," *Journal of risk*, vol. 2, pp. 21–42, (2000).
8. P. M. Esfahani and D. Kuhn, "Data-driven distributionally robust optimization using the Wasserstein metric: Performance guarantees and

tractable reformulations,” Mathematical
Programming, vol. 171, no. 1–2, pp. 115–166,
(2018).