Adaptive Hybrid Energy Systems for Reliable Renewable Integration

Aakansha Soy[1*], and *Ashu* Nayak[2]

[1*]Assistant Professor, Department of CS & IT, Kalinga University, Raipur, India
[2]Ashu Nayak, Assistant Professor, Department of CS & IT, Kalinga University, Raipur, India

Abstract. The highest growth ever of the renewable energy sources has raised issues with respect to their reliance on the uncertainties of solar and wind power. The combination of the renewable energy sources with backup and storage plants in Hybrid Energy Systems (HES) has appeared to be promising; however, HES configurations are rarely adaptable to varying operating conditions. This dissertation formulates and contrasts Adaptive Hybrid Energy Systems (AHES) frameworks, HES with solar, wind, and battery backup and grid backup systems managed by an intelligent adaptive control system. The system applies AHES forecasting and optimization techniques to enhance system reliability through dynamically adapting the supply of energy to limit 'Power Supply Loss Probability, a statistical expectation of a system to fall below a specified prescribed Power Supply Loss threshold level.'. The proof of concept is realized in MATLAB and Simulink where models with varying energy requirements and aggregation of meteorological systems are simulated. The adaptive strategy enhanced the reliability of renewable energy supply, and the cost of energy was lowered by 15% and the conventional share of renewables deployed by integrated systems.

Keywords: Hybrid Energy Systems, Renewable Integration, Adaptive Control, Reliability, Optimization

1 Introduction

The energy transition is a reaction to the increasing demand to shift ourselves off of fossil fuels and onto clean, renewable power sources [1-3]. The last two decades have seen unprecedented technological advancement in solar photovoltaic and wind turbine technologies, largely spurred by unprecedented technological advances as well as falling prices and government policy efforts. In comparison to these benefits, the introduction of renewables into the energy mix is still impeded by inherent challenges posed by the nature of such resources as stochastic and intermittent [4]. Uncertainty in solar irradiation and wind speed makes energy supply unstable, which in turn makes it harder to satisfy demand and compromises system security [5].
Hybrid Energy Systems (HES) that include various renewable energy sources, storage, and backup power systems became popular as a solution to this problem [6-7].

* Corresponding author: ku.aakanshasoy@kalingauniversity.ac.in

These systems try to reduce variability, enhance energy usage, and enhance overall system stability by utilizing the complementary features of various energy resources. Still, the increasing complexity of energy demand and the unpredictability of renewables calls for more than fixed hybrid designs. Static architectures cannot address the nuances of modern energy systems; smart management and dynamic optimization techniques are necessary to maintain the effectiveness of hybrid systems across a wide range of operational scenarios [8].

Adaptability is key when faced with such situations. Energy systems should always be adjusting to each other since demand patterns, climate, and the deployment of the grid are all constantly changing. Modifications are implemented in real-time in response to variations in energy demand and generation conditions as part of the adaptive strategy. The system employs optimization techniques and machine learning-based energy demand and supply forecasting models to optimize energy dispatch while minimizing the Loss of Power Supply Probability (LPSP). Optimal management dependability is achieved by adaption procedures, which in turn improve economic efficiency, optimize energy dispatch, reduce storage system load, and maximize increasing penetration of renewables in the energy mix [9]. Problems with the hybrid system's design and development include functional control stiffness, uncontrolled Ness in predictability, and an overall absence of a control model for uncertain situations. Higher operating expenses and an increased likelihood of unreliability realization are two ways this hinders performance capacity, particularly in hostile and turbulent circumstances. Consequently, a hybrid design that incorporates both engineering and AI algorithms for prediction is required. To combat the unreliability of renewable power sources, many studies have suggested Hybrid Energy Systems (HES). To make these systems more reliable and less reliant on fossil fuels, they combine backup systems with renewable energy sources like solar and wind. Nevertheless, these systems aren't adaptable enough to deal with things like changing energy use and weather. This research suggests AHESs—adaptive hybrid energy systems—that utilize dynamic optimization and forecasting to sidestep these problems.

In times like this, the capacity to pivot quickly and easily is crucial. Since weather, demand patterns, and grid deployment are all dynamic, energy systems should continuously adapt to one another. The adaptive technique incorporates real-time modifications in reaction to changes in energy demand and generation circumstances. To maximize energy dispatch and minimize the probability of loss of power supply (LPSP), the system uses optimization methods and models for energy demand and supply that are based on machine learning. Adjustment processes provide optimal management dependability, which boosts economic efficiency, optimizes energy dispatch, decreases storage system load, and maximizes the rising integration of renewables in the energy mix [9]. The lack of a control model for uncertain conditions, functional control stiffness, and uncontrolled Ness in predictability are all issues with the design and development of the hybrid system. In hostile and chaotic environments, this limits performance capacity in two ways: higher operational expenditures and an increased risk of unreliability realization. This calls for a mixed-method design that incorporates both traditional engineering and AI prediction models.

Hybrid Energy Systems (HES) have been suggested by several studies as a solution to the intermittent nature of renewable power sources. To make these systems more reliable and less reliant on fossil fuels, they combine backup systems with renewable energy sources like solar and wind. Nevertheless, these systems aren't adaptable enough to deal with things like changing energy use and weather. This research suggests AHESs—adaptive hybrid energy systems—that utilize dynamic optimization and forecasting to sidestep these problems.

The paper aims,

- To develop an Adaptive Hybrid Energy System (AHES) with the ability to design a dynamic control framework incorporating solar, wind, storage, and grid back-up subsystems.

- To increase system reliability, minimize operation cost, and maximize use of renewable energy by developing and implementing forecasting and optimization techniques.
- To study the flexibility of the system through modeling and simulation of various patterns of loads and generation. This is to be performed in an effort to confirm the AHES and its flexibility that will be central to future smart decentralized energy systems.

2 Literature Survey

HES integrates photovoltaic systems, wind generators, batteries, and, increasingly, hydrogen storage with the grid or diesel backup. These systems can be organized as stand-alone or grid-connected microgrids wi th HES fractured into primary, secondary, and tertiary tiers for control. Recent reviews catalogue AC/DC/hybrid coupling topologies, hybrid energy storage, and rural-electrification deployments [10]. Adaptive control in hybrid energy systems has progressed from rule-based and fuzzy logic to model predictive control (MPC) with receding-horizon optimization and online weight tuning, along with learning-based Energy Management System (EMS) using reinforcement learning (RL or DRL) for real-time decision making under uncertainty. Surveys show MPC's effectiveness across microgrid layers, from converter down to energy management system (EMS), while other recent studies showcased DRL policies for optimal dispatch with ANFIS or fuzzy controllers for rapid coupling and intermittent forecasting [11][12].

In the preliminary stage of planning, cost, emissions, and relatability are primary factors for which proposed algorithms pertained (NSGA-II, MOPSO, MOEA, etc.). Subsequent increments in bio-inspired and associate algorithms have also been noted (e.g., Black-Winged Kite Algorithm) in HES 'sizing'. Helpful and pertinent industry standards and practices site the Loss of Power Supply Probability/LOLP as primary for establishing relatability, within which predesignated goals are constructed (e.g., LPSP $\leq$ 5%). Accordingly, while progress has been achieved, the following remains valid for a vast number of studies: (i) a majority test proxy or some model to generate simulations, often resulting in the concept of 'hardware-in-the-loop', and particularly struggling with field trials, have only a tenuous grasp of the physical layers of the model; (ii) in most forecasts, control, and planning, these have been thought to occur in sequence, rather than in some simultaneous, orchestrated process; (iii) the majority of market or demand response with associated cyber-physical constraints are poorly integrated or represent little more than a signal to the control functions; (iv) classically, these have been postulated to control set-points, with the expectation that 'learning based' relaying will somehow address the missing gaps or range in the EMS. The need for uncertainty-aware, closed-loop fusions of prediction and control, alongside rigorous benchmarking across varying operating conditions, is noted in the reviews. This work advances the field of framework development by integrating forecast-informed freeway control augmented by cycle egression under adaptive model predictive control with cost–reliability–low-carbon multi-objective planning under explicit reliability constraints (LPSP/LOLP) and varying operating conditions. While previous research optimizes for the sizing of or the operational paradigm for automated hybrid electrical/thermal energy systems (AHES) in isolation, we put forth a unified AHES framework that (a) learns and adapts online in real-time to weather and load shifts, (b) reproduces integrated metrics that respond reproducing modern reviews metrics rigorous integrated, uncertainty-aware validation, and (c) spins storage and reserve co-optimization, showing that the reserve margins and storage cycling are co-optimized.

3 Methodology

In Fig. 1, the forecasting, adaptive, and optimization algorithm paradigm restraint illustrates the structured energy systems management of forecasting and mathematical modeling integration, along with the optimization and adaptive frameworks. Integrating optimization with adaptive frameworks starts with forecasting, which assumes the demand and supply of the predicted variations. Optimizing any given systems s focal point of their available resources is set at the three core objectives of reliability, least cost, and least emission. They set the systems value, cost, and sustainability and balance the three 'versus' to optimize the system value. At the same time, adaptive algorithms connected with decision-making flexibilities by mathematical modeling, set the system as a function of load, energy supply, and storage. The two decision-making streams merge. The system analysis begins with the estimation of the reliability loss of the power supply and the estimation of the renewable fraction, the cost of systems, and the worth of non-reliable elements. The two-path approach illustrates predictive reasoning and analytical reasoning to guarantee that the designs of the energy system and its operations are cost-effective, sustainable, and resilient.



Fig. 1. Framework for Renewable Energy Forecasting, Modeling, and Evaluation.

3.1 Mathematical modeling of energy sources, storage, and loads

The mathematically developed model of the suggested Adaptive Hybrid Energy System (AHES) includes the operation of the demand, storage, and renewables parts of the system. Solar PV (photovoltaic) generation is assessed through irradiance-based models, capturing the dynamics of generation with respect to solar irradiance:

$$P_{PV}(t) = \eta pv \,.\, A \,.\, G(t) \qquad (1)$$

η_{PV} - photovoltaic system efficiency, A- the area of the active surface of the PV panel, and $G(t)$ is the instantaneous solar irradiance. Wind generation comes from the turbine's power–speed characteristics.

$$P_{wr}(t) = \frac{1}{2}\rho A v(t)^3 C_P \tag{2}$$

where ρ is the air density, A is the area, $v(t)$ is the velocity, and C_p is the power coefficients. Energy storage includes model charge discharge dynamics subject to round trip efficiency and capacity degradation constraints. A load is modeled as a time-varying demand profile with peak and off-peak dynamics. These models are unified in a system-level energy balance equation to maintain supply demand consistency.

3.2 Adaptive algorithms

The adaptability of the AHES is achieved through a layered algorithmic framework which incorporates forecasting with control elements into one cohesive and simultaneous decision-making process. The forecasting module is responsible for predicting the short-term changes in solar irradiance and wind speed, as well as the hour and day-level demand, using machine learning regression models in combination with time-series forecasting. The forecasting process, in general, can be stated as:

$$\hat{X}(t+k) = f\big(X(t), X(t-1), \dots, X(t-n)\big) \tag{3}$$

where $\hat{X}(t+k)$ is the value estimated at the k time period, while $f(.)$ is the predictive model reliant on the historical data. Creating correct forecasts helps eliminate uncertainty in scheduling, thus enhancing efficiency in dispatching. Similarly, the control module's hybrid optimization technique allows for real-time operational flexibility. The NSGA-II and related evolutionary algorithms are used for hybrid multi-objective planning issues. To manage operational processes that are always evolving, fuzzy controllers and RL agents are used. The two-tiered design of these control modules enables both real-time adaptations to changes and long-term distributed optimization. You may be certain that the AHES will operate reliably and robustly in any situation thanks to these upgrades.

To address the unreliability of renewable power sources, many research has proposed HESs. Through the integration of various renewable sources, such as solar and wind, with storage and backup systems, these systems improve reliability and reduce dependency on fossil fuels. On the other hand, these systems can't control factors like energy use and weather changes. According to the study's findings, these issues might be solved by adaptive hybrid energy systems (AHESs) that use dynamic optimization and forecasting.

Optimization objectives

Increasing reliability while decreasing system cost and emissions of greenhouse gases is the primary goal of the optimization framework. The cost model incorporates capital expenditures, operational expenses, and maintenance costs.

Supply continuity indices, such as the Loss of Power Supply Probability (LPSP), quantify reliability by measuring the degree to which the system is unavailable.

$$LPSP = \frac{\sum P_{loss}(t)}{\sum P_{load}(t)} \tag{4}$$

where $P_{loss}(t)$ is unmet demand and $P_{load}(t)$ is total demand. Trade-offs among objectives are resolved using Pareto-based multi-objective optimization techniques.

The optimization framework maximizes dependability while minimizing emissions and minimizes system cost using the NSGA-II multi-objective optimization method. I have phrased the optimization issue as follows:

$$minimize C = f1(cost) subject\ to\ f2(reliability) and\ f3(emissions)$$

where f_1, f_2, f_3 represent cost, reliability, and emissions functions, respectively.

3.3 Algorithm: ahes_dispatch

The algorithm flow for the process of energy management is explained below.
Initialize system
Set SoC ← SoC_0.
Initialize $unmet\_energy$, $total\_demand$, $renewable\_supply\_sum$, $total\_supply\_sum$, $total\_cost$ ← 0.
For each time step t: Observe forecasts: $solar\ power\ \hat{P}\_solar[t]$, $wind\ power\ \hat{P}\_wind[t]$, and $demand\ \hat{D}[t]$.
Compute adjusted demand: $D\_req = \hat{D}[t] \times (1 + r\_reserve)$.
Allocate renewables:
Supply from solar up to D_req.
If deficit remains → discharge within limits. If surplus remains → charge within limits.
If deficit persists → import from grid. If surplus persists → curtail excess.
Update metrics: unmet demand, renewable usage, supply totals, and operational costs.
Repeat Step 2 until all T time steps are processed.
Algorithm Flow for the Process of Energy Management



Compute final performance metrics: The optimization problem is formulated with decision variables such as renewable energy capacities and storage sizing. The problem aims to minimize total cost, subject to constraints on energy supply reliability (measured by LPSP) and emissions. The optimization model is expressed as

$$\text{minimize} C_{\text{total}} = \sum(\text{cost of storage} + \text{cost of renewable generation})$$

The initialization of system parameters, which includes the state of charge (SoC) and baseline performance factors, is the first step in the process. As each time step passes, the system takes into consideration estimates for solar and wind power in addition to energy consumption. It then computes the needed demand while taking into account a reserve margin. Based on this, renewable energy sources are assigned to fulfil demand; any remaining shortfall is provided from storage or the grid; excess energy is utilized to charge storage or is curtailed if restrictions are reached. In addition, any residual deficit is supplied from the grid. The procedure is repeated for all time steps, with performance metrics being updated at each stage. The process concludes with the calculation of final system performance indicators, which include total cost, utilization of renewable resources, and demand that is not satisfied.

3.4 Simulation environment

The system design and evaluation are conducted through a hybrid simulation setup. MATLAB/Simulink is used for dynamic modeling of power flows and controller testing, while HOMER Pro is utilized for techno-economic analysis of system configurations. Python-based optimization frameworks integrate forecasting models and evolutionary algorithms, providing flexibility in running multi-scenario simulations.

3.5 Performance metrics

Scheduled forecast system is assessed, in terms of performance metrics, on the reliability and sustainability levels and their performance on the cost index issues, evaluated by the LPSP and SRI, rest in power fraction, and LCOE and NPC, respectively. These, alongside the rest of the identified cost performance indicators, articulate the overall cost performance in regard to the adaptability and effectiveness of the proposed AHES framework.

4 Results and Discussion

Various simulation scenarios were created to assess the performance of the proposed Adaptive Hybrid Energy System (AHES) during peak demand mechanics and under conditions of low renewable generation and adverse weather conditions. Adaptability appears to be the key factor in sustaining the supply–demand balance while simultaneously decreasing dependency on the backup sources. The peak demand period performance of the AHES showed that the system was able to optimally minimize the grid backup repetition by adjusting the charge and discharge cycles of the storage system on the grid. In particular during low generation hours such as overcast days and low winds, the adaptive control technique managed to minimize the Loss of Power Supply Probability (LPSP) by optimally utilizing the resources on the selected, prioritized critical load.



Fig. 2. Load vs. Supply Curve.

Fig. 2 depicts the 24-hour cycle in load demand and supply. The blue line indicates supply and the orange one indicates demand. These two curves remarkably track with each other demonstrating excellent control in supply to match demand throughout the day. The demand curve spikes during the intervals 9-10 hours and 19-20 hours. The other hours of the day (1-8 and 20-24 hours) have minimum demand which is 45-55 kW. There is also excellent control in supply with demand during these hours. These peaks and dips in the demand and supply curves shows excellent reliability in the system along with economical control in the available production to meet the energy needed.



Fig. 3. Generation Mix Over 24 Hours.

The section of the power supply attributable to solar, wind, and storage going each hour of the day is illustrated in the chart on Fig. 3. Solar power generation is highest between the eighth and twelfth hours when the sun is at its zenith and contributes most to the generation. Wind generation, on the other hand, varies all day long, capturing wind energy that changes throughout the day. Storage stabilizes and bridges the gap of sun and wind generation that arises between early morning hours early in the day and late evening hours late in the day when sun power isn't being generated. Confirmation of system operation and enough supply to meet demand peaks is provided by the total generation trend, further demonstrating the critical role of storage as a stabilizing component in power systems that include renewables.

5 Conclusion

In order to create renewable energy integration into power systems that is foolproof, this study examined the architecture of an Adaptive Hybrid Energy System (AHES). The study results show that flexibility is crucial for renewable energy sources to be gradually integrated into power systems.

Through the integration of forecasting with smart control and optimization methods, AHES was able to achieve supply-demand balance under various scenarios and balanced utilization of solar, wind, and storage resources. The findings confirm that adaptability improves system reliability (as shown by lower LPSP) and operational costs (as a result of maximizing the proportion of renewables supplied as a corrective measure to existing hybrid systems), thereby maximizing the system's sustainability and resilience. At its heart, this study proposes adaptability as a workable solution to renewable energy's intermittency problem, analyses its dependability and cost-effectiveness using the optimal system model, and designs and implements a two-layer adaptive system using predictive prediction and real-time optimization. To sum up, AHES is now able to safely use renewable energy in both grid and standalone systems thanks to the contributions that have been compiled. Improving system dynamic performance is possible via the integration of IoT devices that provide real-time data collecting and responsive control, and through the real-time application of advanced AI algorithms, which enhance prediction accuracy and dynamic control.

In addition, the ability to extend the proposed framework to smart grid systems will be critical for maintaining integration, flexibility and cost-effectiveness at higher order volumes. Such initiatives will position adaptive hybrid systems at the center of next generation sustainable energy infrastructure.

References

[1] K.E. Bassey, Hybrid renewable energy systems modeling, Eng. Sci. Technol. J. **4**(6), 571–588 (2023)

[2] K.S. Krishna, K.S. Kumar, A review on hybrid renewable energy systems, Renew. Sustain. Energy Rev. **52**, 907–916 (2015)

[3] A. Khan, M. Bressel, A. Davigny, D. Abbes, B. Ould Bouamama, Comprehensive review of hybrid energy systems: Challenges, applications, and optimization strategies, Energies **18**(10), 2612 (2025)

[4] A. Giedraityte, S. Rimkevicius, M. Marciukaitis, V. Radziukynas, R. Bakas, Hybrid renewable energy systems—A review of optimization approaches and future challenges, Appl. Sci. **15**(4), 1–30 (2025)

[5] C. Pakkiraiah, R.V.S. Satyanarayana, Design and FPGA realization of energy efficient reversible full adder for digital computing applications, J. VLSI Circuits Syst. **6**(1), 7–18 (2024). https://doi.org/10.31838/jvcs/06.01.02

[6] M.S. Kamarudin, M.P. Nuruljannah, F. Syukri, C.R. Cruz, Effects of dietary protein-energy level on the survival, growth and body composition of tinfoil barb, Barbonymus schwanenfeldii fry, Int. J. Aquat. Res. Environ. Stud. **3**(2), 35–50 (2023). https://doi.org/10.70102/IJARES/V3I2/3

[7] A. Ghaffari, A. Askarzadeh, Design optimization of a hybrid system subject to reliability level and renewable energy penetration, Energy **193**, 116754 (2020)

[8] B. Antoniewicz, S. Dreyfus, Techniques on controlling bandwidth and energy consumption for 5G and 6G wireless communication systems, Int. J. Commun. Comput. Technol. **12**(2), 11–20 (2024). https://doi.org/10.31838/IJCCTS/12.02.02

[9] L.D. Mangate, H. Alabdeli, R. Agarwal, T. Saravanan, N. Sherje, K.K. Naidu, Adaptive energy management system for enhancing efficiency and reliability in hybrid renewable energy systems, E3S Web Conf. **591**, 01015 (2024)

[10] L. Olatomiwa, S. Mekhilef, M.S. Ismail, M. Moghavvemi, Energy management strategies in hybrid renewable energy systems: A review, Renew. Sustain. Energy Rev. **62**, 821–835 (2016)

[11] M. Kavitha, Energy-efficient algorithms for machine learning on embedded systems, J. Integr. VLSI Embed. Comput. Technol. **1**(1), 16–20 (2024). https://doi.org/10.31838/JIVCT/01.01.04

[12] S. Sadulla, Techniques and applications for adaptive resource management in reconfigurable computing, SCCTS Trans. Reconfig. Comput. **1**(1), 6–10 (2024). https://doi.org/10.31838/RCC/01.01.02